

令和2年 4月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	雨	14.0	16.0	0.0	7.5							
2	晴	15.0	16.4	0.1	7.6							
3	晴	12.0	16.1	0.0	7.5							
4	晴	15.0	15.9	0.0	7.5							
5	晴	15.0	15.9	0.0	7.5							
6	晴	14.0	16.3	0.0	7.4							
7	晴	14.0	16.2	0.0	7.3							
8	晴	14.0	16.0	0.0	7.3	41.6	49.5	123	5.4	<0.03	<0.02	
9	晴	18.0	16.3	0.0	7.4							
10	晴	15.0	16.3	0.0	7.4							
11	晴	14.0	15.7	0.0	7.4							
12	晴	14.0	15.7	0.0	7.3							
13	雨	10.0	15.8	0.0	7.2							
14	晴	14.0	16.1	0.0	7.4							
15	晴	14.0	16.0	0.0	7.2							
16	曇	15.0	16.1	0.0	7.3							
17	曇	16.0	16.0	0.0	7.2							
18	雨	13.0	15.7	0.2	7.3							
19	晴	17.0	15.9	0.0	7.2							
20	雨	10.0	16.0	0.2	7.2							
21	晴	17.0	16.3	0.1	7.2	40.1	52.5	111	5.5	<0.03	<0.02	
22	曇	16.0	16.2	0.0	7.4							
23	晴	14.0	16.1	0.0	7.4							
24	晴	15.0	16.4	0.0	7.5							
25	晴	14.0	15.9	0.1	7.4							
26	晴	19.0	16.1	0.0	7.3							
27	晴	18.0	16.3	0.0	7.2							
28	晴	16.0	16.1	0.0	7.2							
29	晴	16.0	16.0	0.0	7.2							
30	晴	21.0	16.3	0.0	7.2							
31												
平均		15.0	16.1	0.0	7.3	40.9	51.0	117	5.4	<0.03	<0.02	
最高		21.0	16.4	0.2	7.6	41.6	52.5	123	5.5	<0.03	<0.02	
最低		10.0	15.7	0.0	7.2	40.1	49.5	111	5.4	<0.03	<0.02	