

令和2年10月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	曇	20.7	16.5	0.0	7.4							
2	晴	22.4	16.6	0.0	7.4							
3	晴	21.2	16.4	0.0	7.4							
4	曇	21.6	16.4	0.0	7.4							
5	曇	24.0	16.7	0.0	7.4							
6	晴	23.4	16.4	0.0	7.4							
7	曇	21.3	16.5	0.0	7.4							
8	雨	17.2	16.4	0.1	7.3	48.3	50.6	129	4.6	<0.03	<0.02	
9	雨	18.3	16.5	0.0	7.3							
10	雨	19.1	16.5	0.2	7.3							
11	曇	22.8	16.5	0.0	7.3							
12	晴	24.7	16.5	0.0	7.3							
13	晴	24.5	16.5	0.0	7.3							
14	曇	21.8	16.6	0.0	7.3							
15	曇	21.5	16.3	0.0	7.4							
16	曇	17.6	16.4	0.0	7.4							
17	雨	13.9	16.7	0.0	7.3							
18	曇	15.1	16.3	0.0	7.3							
19	曇	16.3	16.3	0.0	7.3	49.0	50.1	122	4.5	<0.03	<0.02	
20	晴	15.4	16.4	0.0	7.4							
21	曇	15.7	16.5	0.0	7.4							
22	曇	19.3	16.6	0.0	7.4							
23	雨	19.2	16.5	0.0	7.3							
24	晴	16.0	16.4	0.0	7.3							
25	晴	13.5	16.1	0.0	7.3							
26	晴	15.1	16.6	0.0	7.4							
27	晴	18.2	16.7	0.0	7.4							
28	晴	14.8	16.6	0.0	7.3							
29	晴	16.6	16.4	0.0	7.4							
30	晴	16.7	16.6	0.0	7.3							
31	晴	9.3	16.1	0.0	7.4							
平均		18.6	16.5	0.0	7.3	48.7	50.3	126	4.5	<0.03	<0.02	
最高		24.7	16.7	0.2	7.4	49.0	50.6	129	4.6	<0.03	<0.02	
最低		9.3	16.1	0.0	7.3	48.3	50.1	122	4.5	<0.03	<0.02	