

令和2年11月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	12.1	16.4	0.0	7.3							
2	雨	17.9	16.4	0.0	7.3							
3	晴	17.5	16.6	0.0	7.3							
4	晴	14.2	16.3	0.0	7.3							
5	晴	13.5	16.3	0.0	7.3							
6	曇	12.5	16.3	0.0	7.3							
7	曇	15.5	16.4	0.0	7.3							
8	曇	18.8	16.4	0.0	7.2							
9	晴	14.9	16.5	0.0	7.3							
10	晴	12.7	16.4	0.0	7.3							
11	晴	11.0	16.1	0.0	7.4	48.5	49.8	114	4.6	<0.03	<0.02	
12	晴	11.9	16.3	0.0	7.4							
13	晴	14.6	16.3	0.0	7.5							
14	晴	10.5										工水断水作業
15	曇	11.1	16.1	0.0	7.3							
16	晴	16.9	16.4	0.0	7.4							
17	晴	15.6	16.3	0.0	7.3							
18	曇	15.9	16.6	0.0	7.4							
19	晴	16.5	16.5	0.1	7.2	48.7	41.8	130	4.7	<0.03	<0.02	
20	雨	21.2	16.6	0.0	7.1							
21	晴	15.0	16.3	0.0	7.2							
22	晴	11.5	16.1	0.0	7.2							
23	晴	19.0	16.1	0.0	7.2							
24	曇	15.0	16.2	0.0	7.2							
25	雨	14.1	16.3	0.0	7.2							
26	晴	13.3	16.2	0.0	7.2							
27	曇	13.2	16.1	0.0	7.2							
28	晴	16.9	16.2	0.0	7.2							
29	曇	16.2	16.1	0.0	7.2							
30	曇	7.5	16.2	0.0	7.2							
平均		14.6	16.3	0.0	7.3	48.6	45.8	122	4.7	<0.03	<0.02	
最高		21.2	16.6	0.1	7.5	48.7	49.8	130	4.7	<0.03	<0.02	
最低		7.5	16.1	0.0	7.1	48.5	41.8	114	4.6	<0.03	<0.02	