

令和3年 1月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	4.6	15.7	0.0	7.3							
2	晴	1.0	15.6	0.0	7.3							
3	晴	4.8	15.7	0.0	7.3							
4	晴	6.5	15.9	0.0	7.3							
5	曇	5.2	16.0	0.0	7.3							
6	晴	6.9	16.1	0.0	7.3							
7	晴	9.6	15.8	0.1	7.4	47.1	49.2	119	4.8	<0.03	<0.02	
8	晴	3.8	15.6	0.0	7.4							
9	晴	1.2	15.8	0.0	7.4							
10	晴	3.3	15.7	0.0	7.4							
11	曇	0.0	15.5	0.0	7.4							
12	曇	5.7	15.8	0.1	7.4							
13	晴	4.1	15.8	0.0	7.3							
14	晴	3.6	15.9	0.0	7.3							
15	晴	9.2	15.9	0.0	7.3							
16	晴	4.3	15.6	0.0	7.3							
17	晴	8.0	16.0	0.0	7.3							
18	晴	5.5	15.7	0.0	7.4							
19	晴	8.4	15.7	0.0	7.4	47.1	50.4	130	4.9	<0.03	<0.02	
20	曇	3.9	15.8	0.0	7.3							
21	晴	5.0	16.1	0.0	7.3							
22	晴	6.7	15.8	0.0	7.3							
23	雨	11.4	15.9	0.0	7.3							
24	雨	7.5	15.8	0.0	7.3							
25	晴	6.9	16.2	0.0	7.3							
26	晴	6.5	15.9	0.0	7.3							
27	曇	11.7	16.1	0.0	7.3							
28	雨	8.5	16.0	0.0	7.2							
29	晴	8.2	15.9	0.1	7.3							
30	晴	0.0	15.7	0.0	7.2							
31	晴	2.8	15.5	0.0	7.3							
平均		5.6	15.8	0.0	7.3	47.1	49.8	125	4.9	<0.03	<0.02	
最高		11.7	16.2	0.1	7.4	47.1	50.4	130	4.9	<0.03	<0.02	
最低		0.0	15.5	0.0	7.2	47.1	49.2	119	4.8	<0.03	<0.02	