

令和3年 2 月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	8.0	15.8	0.0	7.3							
2	雨	13.8	15.8	0.2	7.2							
3	晴	8.0	15.8	0.0	7.3	46.9	50.8	127	4.9	<0.03	<0.02	
4	晴	8.3	15.6	0.0	7.3							
5	晴	4.9	15.7	0.0	7.2							
6	晴	6.0	15.8	0.0	7.2							
7	晴	4.2	15.5	0.0	7.2							
8	晴	10.7	15.7	0.0	7.3							
9	曇	1.6	15.5	0.0	7.3							
10	晴	2.7	15.7	0.0	7.4							
11	晴	0.9	15.7	0.0	7.3							
12	曇	6.9	15.8	0.0	7.4							
13	晴	7.6	16.1	0.0	7.3							
14	曇	11.8	16.2	0.0	7.3							
15	雨	13.2	15.9	0.6	7.4							
16	晴	11.0	15.8	0.1	7.3							
17	晴	10.3	15.7	0.0	7.3							
18	晴	3.7	15.7	0.1	7.3	46.6	46.7	124	4.9	<0.03	<0.02	
19	晴	2.3	15.7	0.0	7.2							
20	晴	6.8	15.6	0.0	7.2							
21	晴	10.9	16.1	0.0	7.3							
22	晴	13.8	15.9	0.0	7.3							
23	晴	16.3	16.0	0.0	7.2							
24	曇	8.6	15.8	0.0	7.3							
25	晴	6.3	15.8	0.0	7.3							
26	曇	8.7	15.8	0.0	7.2							
27	晴	5.5	15.9	0.0	7.3							
28	晴	2.0	15.6	0.0	7.2							
平均		7.7	15.8	0.0	7.3	46.8	48.8	126	4.9	<0.03	<0.02	
最高		16.3	16.2	0.6	7.4	46.9	50.8	127	4.9	<0.03	<0.02	
最低		0.9	15.5	0.0	7.2	46.6	46.7	124	4.9	<0.03	<0.02	