

令和3年3月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	曇	9.5	15.9	0.0	7.3							
2	雨	14.3	16.2	0.0	7.3							
3	晴	8.7	15.9	0.0	7.3							
4	曇	8.8	15.8	0.0	7.3							
5	曇	11.2	15.8	0.0	7.3							
6	曇	12.7	16.1	0.0	7.3							
7	曇	8.1	15.8	0.0	7.3							
8	雨	8.6	15.9	0.0	7.3							
9	晴	10.5	16.1	0.0	7.2							
10	晴	13.8	16.2	0.1	7.3	49.2	53.0	130	5.1	<0.03	<0.02	
11	晴	11.5	16.0	0.0	7.3							
12	曇	12.9	16.0	0.0	7.3							
13	雨	10.6	15.7	1.7	7.2							
14	晴	9.3	16.0	0.1	7.3							
15	晴	12.6	15.9	0.1	7.3							
16	晴	16.5	16.1	0.0	7.3							
17	晴	17.4	16.2	0.0	7.3	48.8	51.1	131	5.1	<0.03	<0.02	
18	曇	12.8	16.0	0.0	7.2							
19	晴	13.1	16.0	0.0	7.2							
20	晴	13.6	15.9	0.0	7.3							
21	雨	14.7	16.0	0.1	7.2							
22	晴	14.7	15.9	0.0	7.3							
23	晴	10.9	16.1	0.0	7.4							
24	晴	11.7	16.1	0.1	7.4							
25	曇	15.5	15.9	0.0	7.4							
26	晴	12.3	16.0	0.0	7.3							
27	晴	11.1	15.9	0.0	7.3							
28	曇	15.4	16.0	0.0	7.3							
29	晴	19.0	16.4	0.3	7.3							
30	晴	19.7	16.4	0.0	7.3							
31	晴	17.9	16.2	0.0	7.2							
平均		12.9	16.0	0.1	7.3	49.0	52.1	131	5.1	<0.03	<0.02	
最高		19.7	16.4	1.7	7.4	49.2	53.0	131	5.1	<0.03	<0.02	
最低		8.1	15.7	0.0	7.2	48.8	51.1	130	5.1	<0.03	<0.02	