

令和3年 8月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	28.7	16.3	0.0	7.3							
2	晴	32.1	16.4	0.0	7.3							
3	晴	30.7	16.3	0.0	7.3							
4	晴	31.7	16.4	0.0	7.3	44.0	50.9	131	5.6	<0.03	<0.02	
5	晴	33.0	16.5	0.1	7.4							
6	晴	32.5	16.6	0.0	7.3							
7	曇	31.1	16.4	0.0	7.4							
8	雨	26.2	16.5	0.3	7.4							
9	曇	28.8	16.2	0.0	7.4							
10	晴	29.0	16.8	0.1	7.4							
11	晴	30.0	16.7	0.0	7.4							
12	曇	27.7	16.4	0.1	7.4							
13	雨	25.2	16.4	0.1	7.4							
14	雨	26.9	16.7	0.0	7.4							
15	雨	27.3	16.3	0.0	7.4							
16	雨	22.4	16.2	0.0	7.4							
17	雨	23.4	16.4	0.1	7.4							
18	曇	29.5	16.4	0.0	7.4							
19	晴	27.2	16.6	0.0	7.3	48.6	45.7	119	5.4	<0.03	<0.02	
20	晴	28.9	16.8	0.0	7.4							
21	曇	26.0	16.1	0.0	7.3							
22	曇	26.7	16.7	0.0	7.4							
23	曇	29.0	16.3	0.0	7.4							
24	曇	30.1	16.4	0.0	7.4							
25	曇	28.6	16.5	0.0	7.4							
26	晴	30.7	16.5	0.0	7.4							
27	晴	31.9	16.5	0.0	7.4							
28	晴	29.6	16.2	0.1	7.3							
29	晴	30.0	16.2	0.0	7.3							
30	晴	29.7	16.8	0.1	7.4							
31	晴	30.7	16.7	0.0	7.4							
平均		28.9	16.5	0.0	7.4	46.3	48.3	125	5.5	<0.03	<0.02	
最高		33.0	16.8	0.3	7.4	48.6	50.9	131	5.6	<0.03	<0.02	
最低		22.4	16.1	0.0	7.3	44.0	45.7	119	5.4	<0.03	<0.02	