

令和3年12月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	18.0	16.3	0.0	7.4							
2	晴	9.2	15.9	0.0	7.4							
3	晴	9.9	16.1	0.0	7.4							
4	晴	4.8	15.5	0.0	7.4							
5	晴	5.8	15.8	0.0	7.4							
6	曇	11.6	16.1	0.1	7.3	48.6	49.7	124	4.5	<0.03	<0.02	
7	曇	12.6	16.1	0.0	7.4							
8	雨	11.1	16.1	0.0	7.4							
9	晴	9.2	16.0	0.0	7.4							
10	晴	8.8	16.0	0.0	7.4							
11	晴	7.0	15.8	0.0	7.4							
12	晴	6.8	15.9	0.0	7.3							
13	晴	13.1	16.0	0.0	7.4							
14	雨	7.5	15.9	0.0	7.3							
15	晴	5.8	15.8	0.0	7.4							
16	晴	7.5	15.9	0.0	7.3							
17	雨	12.0	15.9	0.0	7.3							
18	晴	4.0	15.5	0.0	7.3							
19	晴	0.0	15.6	0.0	7.3							
20	晴	5.1	16.1	0.0	7.4							
21	晴	4.9	15.8	0.0	7.4							
22	晴	5.4	16.1	0.0	7.3	48.3	48.8	123	4.6	<0.03	<0.02	
23	晴	6.0	16.0	0.0	7.4							
24	晴	6.4	15.8	0.0	7.4							
25	曇	10.0	15.9	0.0	7.3							
26	晴	5.0	15.7	0.0	7.3							
27	晴	0.6	15.8	0.0	7.4							
28	晴	5.3	15.8	0.0	7.4							
29	晴	1.7	15.7	0.0	7.4							
30	晴	9.9	15.8	0.0	7.4							
31	曇	5.7	15.6	0.0	7.4							
平均		7.4	15.9	0.0	7.4	48.5	49.3	124	4.5	<0.03	<0.02	
最高		18.0	16.3	0.1	7.4	48.6	49.7	124	4.6	<0.03	<0.02	
最低		0.0	15.5	0.0	7.3	48.3	48.8	123	4.5	<0.03	<0.02	