

令和4年 1月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	-2.4	15.4	0.0	7.4							
2	曇	1.4	15.6	0.0	7.3							
3	晴	2.4	16.4	0.0	7.4							
4	晴	9.9	15.6	0.0	7.4							
5	晴	1.7	15.5	0.0	7.4							
6	曇	4.5	15.7	0.0	7.4							
7	晴	1.8	15.6	0.0	7.3							
8	晴	2.9	15.6	0.0	7.3							
9	晴	3.4	15.7	0.0	7.3							
10	曇	5.2	15.7	0.0	7.3							
11	雨	8.3	15.8	0.0	7.4							
12	晴	6.2	15.7	0.1	7.3	47.6	47.6	124	4.6	<0.03	<0.02	
13	晴	5.9	15.7	0.0	7.4							
14	晴	2.7	15.5	0.0	7.4							
15	晴	-1.9	15.6	0.0	7.4							
16	晴	2.7	15.8	0.0	7.4							
17	晴	4.2	15.9	0.1	7.4							
18	晴	6.8	15.7	0.0	7.3							
19	曇	1.1	15.7	0.1	7.3	47.3	46.3	119	4.6	<0.03	<0.02	
20	晴	0.6	15.8	0.0	7.3							
21	晴	0.0	15.7	0.1	7.3							
22	晴	-0.3	15.6	0.0	7.3							
23	晴	2.7	15.6	0.0	7.3							
24	曇	6.7	15.7	0.0	7.3							
25	曇	5.0	15.7	0.0	7.3							
26	晴	7.0	15.8	0.0	7.3							
27	曇	5.2	15.9	0.0	7.3							
28	曇	6.4	15.8	0.0	7.4							
29	晴	4.7	15.8	0.0	7.3							
30	曇	3.1	15.6	0.0	7.3							
31	晴	5.5	15.7	0.0	7.3							
平均		3.7	15.7	0.0	7.3	47.5	46.9	122	4.6	<0.03	<0.02	
最高		9.9	16.4	0.1	7.4	47.6	47.6	124	4.6	<0.03	<0.02	
最低		-2.4	15.4	0.0	7.3	47.3	46.3	119	4.6	<0.03	<0.02	