

令和4年 2月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	3.8	15.7	0.0	7.3							
2	晴	6.0	15.7	0.0	7.3	47.6	51.3	120	4.5	<0.03	<0.02	
3	曇	4.3	15.7	0.0	7.3							
4	曇	6.5	15.7	0.0	7.3							
5	晴	4.8	15.6	0.0	7.3							
6	晴	3.8	15.5	0.0	7.3							
7	晴	4.2	15.7	0.1	7.4							
8	曇	5.6	15.8	0.0	7.4							
9	晴	3.7	15.8	0.0	7.3							
10	雨	4.7	15.7	0.1	7.3							
11	曇	4.7	15.7	0.0	7.3							
12	晴	3.2	15.7	0.0	7.3							
13	曇	4.2	15.6	0.0	7.3							
14	曇	5.0	15.3	0.0	7.3							
15	曇	3.8	15.6	0.0	7.34							
16	晴	8.1	15.5	0.0	7.3	46.9	47.4	121	4.5	<0.03	<0.02	
17	晴	5.2	15.7	0.0	7.3							
18	晴	2.4	15.8	0.1	7.3							
19	晴	4.0	15.8	0.0	7.3							
20	曇	9.0	15.7	0.0	7.2							
21	晴	5.2	15.7	0.1	7.3							
22	晴	3.5	15.5	0.0	7.2							
23	晴	3.4	15.7	0.0	7.3							
24	晴	5.8	15.8	0.0	7.3							
25	晴	4.5	15.8	0.0	7.3							
26	晴	4.0	15.5	0.0	7.3							
27	晴	12.2	15.6	0.0	7.3							
28	晴	8.9	16.0	0.1	7.4							
平均		5.2	15.7	0.0	7.3	47.3	49.3	121	4.5	<0.03	<0.02	
最高		12.2	16.0	0.1	7.4	47.6	51.3	121	4.5	<0.03	<0.02	
最低		2.4	15.3	0.0	7.2	46.9	47.4	120	4.5	<0.03	<0.02	