

令和4年 3月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	8.0	15.9	0.1	7.2							
2	晴	11.1	16.2	0.1	7.3							
3	晴	10.8	16.0	0.1	7.3	47.4	47.3	120	4.7	<0.03	<0.02	
4	晴	8.7	16.0	0.0	7.3							
5	晴	8.3	15.7	0.0	7.3							
6	晴	7.9	15.6	0.0	7.3							
7	晴	4.5	15.5	0.0	7.4							
8	晴	9.4	15.9	0.1	7.4							
9	晴	8.4	15.8	0.0	7.4							
10	曇	7.6	15.8	0.0	7.4							
11	晴	7.3	15.8	0.0	7.3							
12	晴	11.4	15.8	0.1	7.3							
13	晴	10.2	15.8	0.0	7.3							
14	雨	18.7	16.1	0.1	7.4							
15	曇	20.9	16.2	0.0	7.3							
16	晴	15.9	16.2	0.1	7.3	47.4	48.5	124	4.7	<0.03	<0.02	
17	晴	17.1	16.1	0.0	7.3							
18	曇	10.5	15.8	0.0	7.3							
19	曇	10.6	15.8	0.1	7.3							
20	晴	11.9	15.8	0.0	7.4							
21	曇	10.9	15.7	0.0	7.3							
22	雨	8.7	15.8	0.1	7.3							
23	晴	8.0	15.8	0.1	7.4							
24	晴	9.4	16.0	0.1	7.4							
25	晴	10.7	16.0	0.3	7.4							
26	曇	13.9	16.1	0.0	7.4							
27	曇	18.9	16.1	0.1	7.3							
28	晴	16.8	16.2	0.0	7.3							
29	曇	12.7	16.0	0.1	7.4							
30	曇	15.7	16.1	0.0	7.4							
31	曇	16.8	16.2	0.0	7.4							
平均		11.7	15.9	0.0	7.3	47.4	47.9	122	4.7	<0.03	<0.02	
最高		20.9	16.2	0.3	7.4	47.4	48.5	124	4.7	<0.03	<0.02	
最低		4.5	15.5	0.0	7.2	47.4	47.3	120	4.7	<0.03	<0.02	