

令和4年 4月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	雨	6.6	15.5	0.0	7.3							
2	曇	8.1	15.6	0.0	7.4							
3	雨	9.5	15.6	0.0	7.3							
4	晴	10.2	15.7	0.2	7.2							
5	晴	13.8	16.1	0.1	7.2							
6	晴	15.9	16.2	0.0	7.3	46.5	45.9	128	4.8	<0.03	<0.02	
7	晴	16.6	16.2	0.0	7.3							
8	晴	18.8	16.2	0.0	7.3							
9	晴	16.2	16.1	0.0	7.3							
10	晴	18.5	16.1	0.0	7.3							
11	晴	21.1	16.4	0.0	7.3							
12	晴	21.8	16.3	0.0	7.3							
13	曇	21.4	16.4	0.1	7.3							
14	曇	18.4	16.2	0.1	7.3							
15	雨	14.2	15.8	0.2	7.3							
16	曇	11.4	15.7	0.1	7.3							
17	雨	12.2	15.8	0.1	7.3							
18	雨	14.9	16.1	0.1	7.3							
19	晴	16.9	16.3	0.0	7.3							
20	曇	15.9	16.1	0.0	7.3							
21	曇	17.0	16.1	0.0	7.3	46.5	51.0	125	4.8	<0.03	<0.02	
22	曇	17.7	16.1	0.0	7.3							
23	晴	22.8	16.0	0.0	7.4							
24	雨	20.4	16.1	0.0	7.3							
25	晴	22.3	16.4	0.1	7.4							
26	曇	21.3	16.0	0.0	7.3							
27	曇	23.2	16.3	0.1	7.3							
28	曇	18.1	16.0	0.0	7.3							
29	曇	18.6	16.1	0.0	7.3							
30	晴	15.2	16.0	0.1	7.3							
31												
平均		16.6	16.1	0.0	7.3	46.5	48.4	127	4.8	<0.03	<0.02	
最高		23.2	16.4	0.2	7.4	46.5	51.0	128	4.8	<0.03	<0.02	
最低		6.6	15.5	0.0	7.2	46.5	45.9	125	4.8	<0.03	<0.02	