

令和4年 5月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	曇	16.3	15.9	0.1	7.3							
2	晴	16.2	16.1	0.1	7.2							
3	晴	17.9	16.0	0.0	7.2							
4	晴	18.3	15.9	0.0	7.2							
5	晴	20.2	16.0	0.0	7.2							
6	曇	20.9	16.2	0.1	7.1							
7	晴	22.3	16.0	0.0	7.2							
8	晴	24.4	16.1	0.0	7.1							
9	曇	20.1	16.2	0.0	7.1							
10	晴	18.5	16.2	0.0	7.3							
11	晴	20.5	16.2	0.0	7.4	47.2	46.8	126	4.9	<0.03	<0.02	
12	曇	22.7	16.2	0.0	7.4							
13	雨	20.1	16.1	0.1	7.4							
14	雨	21.3	16.2	0.2	7.4							
15	曇	19.8	15.9	0.0	7.4							
16	雨	16.9	15.8	0.1	7.4							
17	曇	18.3	15.8	0.0	7.4							
18	晴	21.8	16.2	0.0	7.5							
19	晴	22.6	16.2	0.2	7.4	45.9	56.0	125	4.9	<0.03	<0.02	
20	曇	21.2	16.1	0.0	7.3							
21	曇	20.7	15.8	0.1	7.4							
22	晴	20.6	16.0	0.1	7.4							
23	晴	24.2	16.5	0.1	7.4							
24	晴	24.4	16.5	0.1	7.5							
25	晴	25.4	16.3	0.1	7.5							
26	晴	25.5	16.2	0.1	7.4							
27	曇	21.4	16.3	0.2	7.4							
28	晴	25.2	16.1	0.1	7.4							
29	晴	26.2	16.1	0.3	7.4							
30	晴	27.1	16.4	0.0	7.4							
31	雨	19.3	16.1	0.0	7.3							
平均		21.3	16.1	0.1	7.3	46.6	51.4	126	4.9	<0.03	<0.02	
最高		27.1	16.5	0.3	7.5	47.2	56.0	126	4.9	<0.03	<0.02	
最低		16.2	15.8	0.0	7.1	45.9	46.8	125	4.9	<0.03	<0.02	