

令和4年 9月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考	
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L		
1	雨	27.0	17.4	1.5	7.3								
2			マイクロストレーナーのトラブルによる断水										
3	晴	27.8	16.7	0.1	7.3								
4	晴	28.9	16.4	0.0	7.3								
5	晴	29.3	16.8	0.2	7.4								
6	晴	29.0	16.7	0.2	7.2								
7	曇	27.4	16.5	0.1	7.2								
8	雨	24.4	16.0	0.1	7.3	45.5	51.9	127	5.3	<0.03	<0.02		
9	曇	27.6	16.2	0.0	7.3								
10	晴	28.4	16.1	0.0	7.3								
11	晴	26.5	16.1	0.0	7.3								
12	晴	27.6	16.5	0.0	7.3								
13	晴	28.2	17.0	0.0	7.4								
14	晴	27.4	16.6	0.0	7.4								
15	曇	24.8	16.2	0.0	7.4								
16	晴	26.4	16.6	0.0	7.5								
17	晴	27.6	16.0	0.0	7.4								
18	雨	25.9	16.4	0.3	7.3								
19	曇	27.0	16.2	0.0	7.4								
20	曇	28.5	16.5	0.0	7.3								
21	曇	21.6	16.2	0.1	7.2	46.6	49.8	131	5.4	<0.03	<0.02		
22	晴	23.5	16.1	0.0	7.3								
23	雨	22.0	15.9	0.0	7.2								
24	曇	25.0	16.2	0.2	7.2								
25	晴	25.1	16.5	0.0	7.3								
26	晴	24.0	16.6	0.0	7.4								
27	晴	24.9	16.9	0.0	7.4								
28	晴	24.5	16.2	0.0	7.4								
29	曇	22.1	16.7	0.1	7.4								
30	晴	24.5	16.2	0.1	7.4								
平均		26.1	16.4	0.1	7.3	46.1	50.9	129	5.3	<0.03	<0.02		
最高		29.3	17.4	1.5	7.5	46.6	51.9	131	5.4	<0.03	<0.02		
最低		21.6	15.9	0.0	7.2	45.5	49.8	127	5.3	<0.03	<0.02		