

令和4年10月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	22.8	16.1	0.0	7.3							
2	晴	22.2	16.2	0.0	7.3							
3	曇	22.3	16.3	0.0	7.2							
4	晴	26.4	16.4	0.0	7.2							
5	曇	25.8	16.1	0.0	7.3							
6	雨	15.0	15.8	0.0	7.1	4.6	46.8	124	5.3	<0.03	<0.02	
7	雨	13.6	16.1	0.0	7.2							
8	晴	17.5	16.0	0.0	7.3							
9	曇	19.5	16.0	0.0	7.4							
10	曇	19.4	15.9	0.0	7.3							
11	晴	21.0	16.1	0.0	7.3							
12	曇	18.4	16.0	0.0	7.2							
13	曇	17.1	15.8	0.1	7.3							
14	曇	20.9	16.0	0.0	7.3							
15	晴	22.5	16.0	0.0	7.2							
16	晴	22.3	16.0	0.0	7.3							
17	曇	24.1	16.5	0.0	7.3							
18	曇	20.3	16.4	0.0	7.3							
19	曇	15.6	16.0	0.0	7.3							
20	晴	14.3	16.1	0.2	7.2	47.9	50.2	128	5.4	<0.03	<0.02	
21	晴	16.4	16.1	0.0	7.3							
22	曇	17.4	15.8	0.0	7.3							
23	晴	17.3	15.9	0.0	7.3							
24	曇	17.0	15.9	0.0	7.2							
25	曇	12.1	15.7	0.0	7.2							
26	晴	13.0	16.2	0.0	7.3							
27	晴	11.6	15.8	0.0	7.3							
28	曇	13.8	15.9	0.0	7.2							
29	晴	14.5	15.9	0.0	7.3							
30	曇	12.4	15.7	0.0	7.3							
31	晴	16.4	15.9	0.0	7.3							
平均		18.2	16.0	0.0	7.3	26.3	48.5	126	5.3	<0.03	<0.02	
最高		26.4	16.5	0.2	7.4	47.9	50.2	128	5.4	<0.03	<0.02	
最低		11.6	15.7	0.0	7.1	4.6	46.8	124	5.3	<0.03	<0.02	