

令和4年12月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	曇	14.3	15.8	0.0	7.2							
2	晴	11.4	15.9	0.0	7.2							
3	晴	8.1	15.7	0.0	7.2							
4	晴	13.1	15.7	0.0	7.2							
5	曇	12.4	15.8	0.0	7.2							
6	曇	10.2	15.8	0.0	7.2							
7	晴	7.7	16.0	0.0	7.2							
8	晴	4.9	15.7	0.0	7.2	46.9	54.4	127	5.0	<0.03	<0.02	
9	曇	7.4	15.7	0.0	7.2							
10	晴	6.1	15.6	0.0	7.3							
11	晴	9.0	15.7	0.0	7.2							
12	晴	9.0	15.7	0.0	7.2							
13	曇	7.6	15.7	0.0	7.2							
14	晴	13.3	15.6	0.0	7.3							
15	晴	6.2	15.6	0.0	7.2							
16	晴	6.1	15.8	0.0	7.3							
17	曇	5.3	15.7	0.0	7.3							
18	晴	8.9	15.4	0.0	7.2							
19	晴	6.2	15.6	0.0	7.3							
20	晴	3.2	15.6	0.0	7.2							
21	晴	4.1	15.8	0.0	7.3							
22	雨	8.8	15.6	0.8	7.2	48.0	45.0	128	4.9	—	—	
23	晴	5.4	15.3	0.0	7.3							
24	晴	6.3	15.5	0.0	7.3							
25	晴	1.1	15.5	0.0	7.3							
26	晴	1.2	15.6	0.0	7.2							
27	晴	0.8	15.5	0.0	7.3							
28	曇	4.8	15.6	0.0	7.3							
29	晴	5.1	15.5	0.0	7.3							
30	晴	6.5	15.6	0.0	7.4							
31	曇	4.0	15.5	0.0	7.3							
平均		7.0	15.6	0.0	7.2	47.5	49.7	128	5.0	<0.03	<0.02	
最高		14.3	16.0	0.8	7.4	48.0	54.4	128	5.0	<0.03	<0.02	
最低		0.8	15.3	0.0	7.2	46.9	45.0	127	4.9	<0.03	<0.02	

22日分の鉄・マンガンは、原子吸光光度計の故障のため欠測