

令和5年 2月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	3.0	15.6	0.0	7.2							
2	曇	8.5	16.0	0.0	7.1							
3	晴	7.7	15.7	0.0	7.1							
4	晴	4.4	15.5	0.0	0.2							
5	晴	4.3	15.4	0.0	7.2							
6	晴	3.7	15.6	0.0	7.2							
7	曇	6.7	15.7	0.0	7.2							
8	曇	8.0	15.7	0.0	7.2							
9	晴	5.3	15.6	0.1	7.3	45.2	45.7	121	5.0	<0.03	<0.02	
10	雨	4.8	15.6	0.1	7.3							
11	晴	7.7	15.5	0.0	7.3							
12	曇	8.9	15.8	0.0	7.3							
13	雨	12.3	15.8	0.1	7.2							
14	曇	5.8	15.7	0.0	7.3							
15	曇	4.3	15.6	0.0	7.4							
16	晴	4.5	15.7	0.1	7.3	45.8	50.0	124	5.1	<0.03	<0.02	
17	晴	6.5	15.7	0.0	7.4							
18	晴	5.6	15.6	0.0	7.3							
19	曇	17.1	15.8	0.1	7.3							
20	晴	10.6	16.0	0.0	7.3							
21	晴	6.4	15.8	0.1	7.3							
22	晴	4.1	15.6	0.0	7.3							
23	晴	7.8	15.7	0.0	7.3							
24	晴	8.6	16.0	0.1	7.3							
25	晴	6.4	15.7	0.0	7.3							
26	晴	3.0	15.5	0.0	7.3							
27	晴	3.2	15.7	0.0	7.3							
28	晴	7.7	15.7	0.0	7.3							
平均		6.7	15.7	0.0	7.0	45.5	47.8	123	5.1	<0.03	<0.02	
最高		17.1	16.0	0.1	7.4	45.8	50.0	124	5.1	<0.03	<0.02	
最低		3.0	15.4	0.0	0.2	45.2	45.7	121	5.0	<0.03	<0.02	