

令和5年 3月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	曇	12.5	15.7	0.0	7.3							
2	晴	14.5	16.2	0.0	7.3							
3	曇	7.8	15.6	0.0	7.3							
4	晴	7.8	15.7	0.0	7.3							
5	晴	10.8	15.7	0.0	7.3							
6	晴	10.9	15.9	0.0	7.2							
7	晴	11.3	15.9	0.0	7.2							
8	晴	11.0	16.0	0.0	7.3							
9	晴	12.3	15.8	0.0	7.3	45.4	48.3	124	5.2	<0.03	<0.02	
10	曇	16.5	16.1	0.0	7.4							
11	晴	12.7	15.7	0.0	7.3							
12	曇	12.7	15.8	0.0	7.3							
13	雨	14.0	16.2	0.1	7.3							
14	晴	11.4	16.1	0.1	7.4							
15	晴	12.1	16.3	0.1	7.4							
16	晴	15.2	16.0	0.1	7.4							
17	晴	16.8	16.4	0.1	7.4							
18	雨	11.0	15.6	0.0	7.4							
19	曇	9.9	15.8	0.0	7.4							
20	晴	10.8	16.0	0.0	7.3							
21	曇	12.8	15.8	0.0	7.4							
22	晴	16.5	16.4	0.0	7.3							
23	曇	17.7	16.5	0.2	7.3	46.4	47.0	124	5.3	<0.03	<0.02	
24	晴	21.0	16.3	0.1	7.3							
25	雨	13.1	16.2	0.1	7.3							
26	雨	13.6	15.8	0.0	7.3							
27	曇	14.4	15.4	0.1	7.3							
28	雨	12.0	15.8	0.0	7.3							
29	晴	15.4	16.1	0.0	7.3							
30	晴	14.8	16.3	0.0	7.3							
31	曇	12.7	15.8	0.1	7.3							
平均		13.1	16.0	0.0	7.3	45.9	47.6	124	5.3	<0.03	<0.02	
最高		21.0	16.5	0.2	7.4	46.4	48.3	124	5.3	<0.03	<0.02	
最低		7.8	15.4	0.0	7.2	45.4	47.0	124	5.2	<0.03	<0.02	