

令和5年 4月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考		
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L			
1	晴	13.9	15.9	0.0	7.3									
2	晴	17.1	16.1	0.0	7.4									
3	晴	15.7	16.2	0.0	7.3									
4	晴	14.5	16.0	0.1	7.3									
5	晴	15.3	16.3	0.0	7.3									
6	雨	16.2	16.1	0.2	7.2	46.0	45.8	126	5.3	<0.03	<0.02			
7	曇	19.5	16.3	0.1	7.3									
8	晴	16.8	15.9	0.1	7.3									
9	晴	12.9	15.8	0.0	7.3									
10	晴	12.9	16.1	0.0	7.3									
11	晴	18.8	16.1	0.0	7.3									
12	晴	20.8	16.2	0.0	7.3									
13	晴	16.7	16.3	0.0	7.3									
14	曇	17.5	16.0	0.1	7.3									
15	雨	14.0	15.7	0.0	7.3									
16	晴	19.7	16.1	0.0	7.2									
17	晴	18.8	16.1	0.0	7.3									
18	晴	18.7	16.0	0.0	7.2									
19	晴	20.7	15.9	0.0	7.3	45.3	51.0	130	5.4	<0.03	<0.02			
20	晴	21.5	16.2	0.1	7.3									
21	晴	22.0	16.2	0.0	7.3									
22	曇	16.4	15.9	0.0	7.3									
23	曇	15.8	15.9	0.0	7.3									
24	曇	15.7	15.9	0.1	7.2									
25	晴	18.0	16.1	0.1	7.3									
26	雨	14.9	16.1	0.2	7.2									
27	晴	18.7		無停電電源設備工事のため断水										
28	晴	19.5	16.1	0.1	7.2									
29	曇	19.5	16.1	0.0	7.3									
30	曇	21.3	16.1	0.0	7.3									
31														
平均		17.5	16.1	0.0	7.3	45.7	48.4	128	5.4	<0.03	<0.02			
最高		22.0	16.3	0.2	7.4	46.0	51.0	130	5.4	<0.03	<0.02			
最低		12.9	15.7	0.0	7.2	45.3	45.8	126	5.3	<0.03	<0.02			