

令和5年 5月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	21.0	16.1	0.2	7.1							
2	晴	19.0	16.0	0.1	7.1							
3	晴	19.6	16.0	0.0	7.2							
4	晴	21.2	15.9	0.0	7.2							
5	晴	21.2	16.1	0.0	7.3							
6	晴	23.5	16.2	0.0	7.2							
7	雨	21.5	16.0	0.0	7.2							
8	曇	20.4	16.2	0.2	7.3							
9	晴	17.4	16.1	0.1	7.3							
10	晴	19.4	16.1	0.1	7.3							
11	晴	20.9	16.2	0.2	7.4	45.1	56.9	128	5.7	<0.03	<0.02	
12	晴	20.7	16.2	0.1	7.3							
13	雨	16.5	15.8	0.1	7.3							
14	曇	17.0	15.8	0.0	7.3							
15	雨	16.0	16.2	0.2	7.3							
16	晴	20.4	16.3	0.1	7.4							
17	晴	23.3	16.2	0.1	7.4							
18	晴	26.0	16.7	0.1	7.4							
19	曇	23.5	16.5	0.1	7.4							
20	曇	23.5	16.5	0.0	7.4							
21	曇	22.1	16.0	0.1	7.4							
22	晴	25.6	16.3	0.0	7.4							
23	雨	16.6	16.1	0.2	7.3							
24	晴	19.5	16.1	0.1	7.4							
25	曇	19.0	16.0	0.5	7.3	44.5	41.0	128	5.7	<0.03	<0.02	
26	晴	21.4	16.5	0.0	7.4							
27	晴	22.8	16.2	0.0	7.4							
28	晴	23.0	16.0	0.0	7.3							
29	雨	21.9	16.0	0.1	7.3							
30	雨	19.6	15.9	0.2	7.3							
31	曇	18.8	15.9	0.0	7.3							
平均		20.7	16.1	0.1	7.3	44.8	48.9	128	5.7	<0.03	<0.02	
最高		26.0	16.7	0.5	7.4	45.1	56.9	128	5.7	<0.03	<0.02	
最低		16.0	15.8	0.0	7.1	44.5	41.0	128	5.7	<0.03	<0.02	