

令和5年 7月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残留 物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	雨	24.1	17.1	1.2	7.3							
2	晴	29.5	16.4	0.0	7.3							
3	晴	29.6	16.8	0.1	7.3							
4	晴	28.2	16.8	0.2	7.3							
5	曇	25.0	16.7	0.0	7.3							
6	晴	28.3	16.3	0.1	7.3	42.8	57.6	129	6.0	<0.03	<0.02	
7	晴	30.0	16.9	0.0	7.3							
8	曇	27.7	17.0	0.0	7.3							
9	曇	27.5	16.3	0.0	7.3							
10	曇	27.2	16.4	0.1	7.3							
11	晴	30.7	16.5	0.1	7.3							
12	晴	29.9	16.8	0.0	7.3							
13	曇	26.8	16.6	0.0	7.3							
14	曇	26.7	16.6	0.1	7.2							
15	曇	27.8	16.7	0.0	7.2							
16	晴	29.4	16.5	0.0	7.3							
17	晴	33.0	16.4	0.0	7.2							
18	晴	33.2	16.4	0.0	7.2							
19	晴	30.8	16.5	0.0	7.2							
20	曇	30.0	16.4	0.1	7.2	50.4	48.2	122	5.7	<0.03	<0.02	
21	晴	31.1	16.5	0.0	7.2							
22	晴	30.7	16.3	0.0	7.2							
23	曇	30.0	16.3	0.0	7.3							
24	晴	30.8	16.9	0.0	7.3							
25	晴	30.8	17.0	0.1	7.2							
26	晴	31.2	16.8	0.1	7.2							
27	曇	32.8	16.9	0.2	7.2							
28	晴	31.4	16.6	0.0	7.3							
29	晴	30.1	16.4	0.0	7.3							
30	晴	31.4	16.3	0.0	7.3							
31	晴	31.9	16.6	0.1	7.3							
平均		29.6	16.6	0.1	7.3	46.6	52.9	126	5.8	<0.03	<0.02	
最高		33.2	17.1	1.2	7.3	50.4	57.6	129	6.0	<0.03	<0.02	
最低		24.1	16.3	0.0	7.2	42.8	48.2	122	5.7	<0.03	<0.02	