

令和5年11月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイスト槽)											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残留 物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	14.7	16.0	0.1	7.3							
2	晴	14.0	16.0	0.0	7.3							
3	晴	14.1	16.0	0.1	7.3							
4	晴	18.1	16.1	0.0	7.3							
5	晴	20.6	16.1	0.0	7.3							
6	晴	21.1	16.2	0.0	7.3							
7	晴	24.0	16.4	0.2	7.3	51.0	50.1	123	5.3	<0.03	<0.02	
8	晴	17.1	16.1	0.0	7.3							
9	晴	13.8	16.0	0.0	7.3							
10	雨	16.1	16.1	0.1	7.3							
11	曇	15.7	—	—	—							断水作業により測定不可
12	曇	13.3	15.9	0.0	7.3							
13	雨	10.3	16.0	0.0	7.3							
14	晴	9.4	15.8	0.0	7.4							
15	曇	11.1	16.2	0.0	7.4							
16	晴	10.3	16.1	0.0	7.4							
17	雨	13.1	16.1	1.0	7.4							
18	晴	14.7	15.7	0.0	7.3							
19	晴	8.9	15.4	0.0	7.4							
20	晴	12.8	16.1	0.0	7.4							
21	晴	9.6	15.8	0.0	7.4	51.2	47.7	142	5.2	<0.03	<0.02	
22	晴	11.1	16.0	0.1	7.4							
23	曇	15.5	16.2	0.0	7.4							
24	晴	20.6	16.2	0.1	7.3							
25	晴	11.7	16.0	0.0	7.4							
26	曇	10.8	15.7	0.0	7.4							
27	晴	9.8	16.0	0.0	7.4							
28	晴	18.5	16.2	0.0	7.4							
29	晴	13.0	15.8	0.0	7.4							
30	晴	13.5	15.8	0.0	7.4							
31												
平均		14.2	16.0	0.1	7.3	51.1	48.9	133	5.3	<0.03	<0.02	
最高		24.0	16.4	1.0	7.4	51.2	50.1	142	5.3	<0.03	<0.02	
最低		8.9	15.4	0.0	7.3	51.0	47.7	123	5.2	<0.03	<0.02	