

令和5年12月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイスト槽)											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残留 物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	6.7	15.7	0.0	7.3							
2	晴	5.3	15.6	0.0	7.3							
3	晴	6.6	15.7	0.0	7.4							
4	晴	6.7	15.7	0.0	7.4							
5	曇	6.3	15.7	0.0	7.3	50.7	48.2	136	5.6	<0.03	<0.02	
6	晴	12.1	15.9	0.0	7.3							
7	晴	15.7	15.8	0.0	7.3							
8	晴	8.4	15.8	0.0	7.3							
9	晴	6.9	15.7	0.0	7.4							
10	晴	8.2	15.7	0.0	7.4							
11	曇	9.8	16.1	0.0	7.3							
12	曇	13.7	16.3	0.1	7.4							
13	晴	10.8	15.9	0.0	7.4							
14	晴	10.4	16.2	0.1	7.3							
15	雨	12.6	16.3	0.1	7.3							
16	曇	21.4	16.1	0.0	7.4							
17	晴	10.3	15.4	0.0	7.3							
18	晴	4.7	15.6	0.1	7.3							
19	曇	6.4	15.3	0.1	7.3	53.5	52.2	126	5.3	<0.03	<0.02	
20	晴	8.4	15.8	0.0	7.3							
21	晴	9.0	15.9	0.0	7.4							
22	晴	1.4	15.4	0.0	7.3							
23	晴	0.4	15.5	0.0	7.3							
24	晴	2.1	15.4	0.0	7.4							
25	晴	4.8	15.7	0.0	7.4							
26	晴	4.6	15.7	0.0	7.4							
27	曇	5.1	15.7	0.0	7.3							
28	晴	8.3	15.8	0.0	7.3							
29	晴	4.3	15.4	0.0	7.3							
30	晴	5.6	15.7	0.0	7.4							
31	雨	8.8	15.7	0.0	7.3							
平均		7.9	15.7	0.0	7.3	52.1	50.2	131	5.5	<0.03	<0.02	
最高		21.4	16.3	0.1	7.4	53.5	52.2	136	5.6	<0.03	<0.02	
最低		0.4	15.3	0.0	7.3	50.7	48.2	126	5.3	<0.03	<0.02	