

令和6年 1月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイスト槽)											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	7.7	15.6	0.0	7.4							
2	曇	7.7	15.5	0.0	7.3							
3	晴	5.0	15.6	0.0	7.4							
4	晴	8.7	16.1	0.0	7.3							
5	晴	8.6	16.2	0.1	7.3							
6	晴	8.3	15.7	0.0	7.3							
7	晴	10.0	15.5	0.1	7.4							
8	晴	2.9	15.4	0.0	7.4							
9	晴	2.4	15.5	0.0	7.3							
10	晴	4.2	15.5	0.0	7.3							
11	曇	6.9	15.5	0.0	7.4							
12	晴	1.0	15.6	0.0	7.3							
13	晴	3.1	15.5	0.0	7.4							
14	晴	1.5	15.4	0.0	7.4							
15	晴	12.3	15.7	0.0	7.3							
16	晴	5.0	15.5	0.0	7.4	52.1	53.6	141	5.3	<0.03	<0.02	
17	晴	3.4	15.6	0.0	7.3							
18	晴	6.1	15.6	0.0	7.4							
19	曇	12.2	15.7	0.1	7.2							
20	雨	7.7	15.7	0.0	7.3							
21	雨	9.7	15.5	0.3	7.3							
22	曇	9.7	15.9	0.0	7.3							
23	晴	13.0	15.6	0.1	7.3	50.2	51.5	138	5.5	<0.03	<0.02	
24	晴	3.0	15.6	0.0	7.3							
25	晴	3.9	15.4	0.0	7.3							
26	晴	1.1	16.0	0.0	7.3							
27	晴	1.2	15.7	0.0	7.3							
28	曇	4.1	15.6	0.0	7.3							
29	晴	2.3	15.6	0.1	7.3							
30	晴	4.6	16.2	0.0	7.4							
31	晴	3.7	15.6	0.0	7.3							
平均		5.8	15.6	0.0	7.3	51.2	52.6	140	5.4	<0.03	<0.02	
最高		13.0	16.2	0.3	7.4	52.1	53.6	141	5.5	<0.03	<0.02	
最低		1.0	15.4	0.0	7.2	50.2	51.5	138	5.3	<0.03	<0.02	