

令和6年 2月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイスト槽(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	13.4	16.3	0.0	7.4							
2	曇	6.7	16.5	0.0	7.3							
3	晴	4.6	15.5	0.0	7.4							
4	雨	6.2	15.5	0.0	7.4							
5	曇	6.6	15.6	0.0	7.3							
6	雨	6.4	15.6	0.0	7.4	51.5	48.4	133	5.3	<0.03	<0.02	
7	曇	5.7	15.7	0.0	7.3							
8	晴	4.4	15.6	0.0	7.2							
9	曇	5.1	15.7	0.0	7.3							
10	晴	5.9	15.4	0.0	7.3							
11	曇	3.8	15.5	0.0	7.3							
12	晴	4.4	15.5	0.0	7.3							
13	晴	9.5	16.1	0.0	7.3							
14	晴	9.0	16.1	0.0	7.3							
15	晴	13.6	16.0	0.0	7.2							
16	晴	14.3	16.0	0.0	7.2							
17	曇	9.5	16.1	0.0	7.2							
18	晴	11.9	15.7	0.0	7.2							
19	雨	13.0	16.0	0.1	7.3							
20	曇	18.3	16.5	0.1	7.1	52.2	44.2	141	5.1	<0.03	<0.02	
21	曇	12.3	15.7	0.1	7.3							
22	雨	8.8	15.6	0.2	7.4							
23	雨	5.6	15.7	0.0	7.4							
24	晴	5.0	15.6	0.0	7.4							
25	雨	5.5	15.6	0.1	7.3							
26	曇	9.1	15.8	0.0	7.4							
27	晴	8.5	15.5	0.1	7.4							
28	晴	5.9	15.7	0.0	7.4							
29	晴	8.8	15.8	0.0	7.4							
平均		8.3	15.8	0.0	7.3	51.9	46.3	137	5.2	<0.03	<0.02	
最高		18.3	16.5	0.2	7.4	52.2	48.4	141	5.3	<0.03	<0.02	
最低		3.8	15.4	0.0	7.1	51.5	44.2	133	5.1	<0.03	<0.02	