

令和6年 3月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイスト槽)											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	雨	8.8	15.7	0.0	7.3							
2	晴	7.1	15.6	0.0	7.3							
3	晴	4.7	15.7	0.0	7.4							
4	晴	10.9	15.7	0.1	7.4							
5	曇	9.2	16.0	0.1	7.4	50.1	44.0	141	5.4	<0.03	<0.02	
6	曇	10.2	15.8	0.2	7.3							
7	雨	7.0	15.7	0.0	7.4							
8	曇	8.6	15.8	0.1	7.4							
9	晴	6.7	15.7	0.0	7.4							
10	晴	4.6	15.6	0.0	7.4							
11	晴	5.4	15.7	0.1	7.3							
12	雨	8.9	15.9	0.1	7.3	51.5	43.0	138	5.4	<0.03	<0.02	
13	晴	9.0	15.7	0.0	7.4							
14	晴	9.7	15.8	0.1	7.4							
15	晴	9.3	16.1	0.0	7.4							
16	晴	10.0	15.6	0.0	7.4							
17	曇	11.4	16.0	0.1	7.4							
18	晴	14.8	15.9	0.1	7.4							
19	曇	7.9	15.7	0.0	7.3							
20	晴	13.8	15.6	0.0	7.4							
21	晴	8.1	15.7	0.0	7.3							
22	晴	7.7	15.7	0.0	7.3							
23	雨	6.2	15.5	0.0	7.3							
24	曇	9.9	15.6	0.1	7.3							
25	雨	13.2	15.9	0.1	7.3							
26	雨	10.6	15.7	0.6	7.2							
27	晴	9.8	15.8	0.1	7.3							
28	曇	10.8	15.5	0.1	7.2							
29	雨	17.6	16.0	0.3	7.3							
30	晴	20.1	15.8	0.0	7.3							
31	晴	21.7	16.5	0.0	7.3							
平均		10.1	15.8	0.1	7.3	50.8	43.5	140	5.4	<0.03	<0.02	
最高		21.7	16.5	0.6	7.4	51.5	44.0	141	5.4	<0.03	<0.02	
最低		4.6	15.5	0.0	7.2	50.1	43.0	138	5.4	<0.03	<0.02	