

令和6年 8月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	31.4	16.6	0.1	7.3							
2	晴	32.2	16.4	0.1	7.3							
3	晴	31.0	16.4	0.0	7.3							
4	曇	29.8	16.4	0.0	7.4							
5	晴	32.0	17.0	0.1	7.4	52.2	49.9	149	5.5	<0.03	<0.02	
6	晴	32.1	16.9	0.2	7.4							
7	晴	30.1	16.7	0.1	7.4							
8	晴	29.4	16.7	0.1	7.4							
9	晴	31.2	16.5	0.1	7.4							
10	晴	28.1	17.0	0.0	7.4							
11	晴	30.2	16.4	0.1	7.5							
12	晴	31.4	16.6	0.0	7.3							
13	晴	30.6	16.6	0.1	7.2							
14	晴	30.4	16.5	0.0	7.3							
15	晴	31.3	16.7	0.1	7.3							
16	曇	29.8	16.8	0.1	7.2							
17	晴	30.6	16.6	0.0	7.3							
18	晴	30.3	16.3	0.0	7.3							
19	晴	31.0	16.6	0.0	7.3							
20	晴	28.2	16.5	0.1	7.2	50.8	50.2	126	5.4	<0.03	<0.02	
21	晴	30.5	16.6	0.1	7.2							
22	曇	28.5	16.3	0.1	7.2							
23	曇	27.3	16.5	0.1	7.3							
24	曇	30.3	16.5	0.0	7.3							
25	晴	30.1	16.5	2.9	7.3							
26	晴	28.2	16.9	0.2	7.4							
27	雨	26.6	16.6	0.2	7.4							
28	曇	26.8	16.4	0.1	7.4							
29	曇	27.0	16.6	0.1	7.4							
30	曇	26.9	16.5	0.2	7.4							
31	曇	27.7	16.5	0.1	7.4							
平均		29.7	16.6	0.2	7.3	51.5	50.1	138	5.5	<0.03	<0.02	
最高		32.2	17.0	2.9	7.5	52.2	50.2	149	5.5	<0.03	<0.02	
最低		26.6	16.3	0.0	7.2	50.8	49.9	126	5.4	<0.03	<0.02	