

令和6年11月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	17.2	16.6	0.1	7.4							
2	雨	18.7	16.3	0.1	7.3							
3	曇	18.9	16.4	0.2	7.4							
4	晴	14.8	16.1	0.1	7.4							
5	曇	16.3	16.2	0.1	7.3							
6	曇	16.1	16.3	0.0	7.4	52.7	52.5	129	5.0	<0.03	<0.02	
7	晴	15.0	16.4	0.0	7.5							
8	曇	12.8	15.9	0.1	7.4							
9		定期断水作業										
10	曇	16.4	16.0	0.0	7.4							
11	曇	18.8	16.2	0.0	7.3							
12	曇	16.4	16.1	0.0	7.3							
13	晴	16.5	16.2	0.1	7.3							
14	曇	14.2	16.1	0.2	7.3							
15	曇	17.3	16.2	0.1	7.3							
16	曇	17.9	16.4	0.0	7.3							
17	晴	18.2	16.2	0.0	7.3							
18	曇	17.8	16.5	0.0	7.3							
19	晴	11.8	16.0	0.0	7.4	52.3	50.4	119	4.9	<0.03	<0.02	
20	雨	9.4	16.2	0.0	7.4							
21	晴	13.6	16.4	0.0	7.4							
22	晴	12.4	16.2	0.0	7.3							
23	曇	11.1	15.9	0.0	7.3							
24	曇	11.7	15.9	0.0	7.3							
25	晴	10.4	16.2	0.0	7.3							
26	晴	9.2	16.3	0.1	7.3							
27	晴	18.1	16.1	0.1	7.3							
28	晴	15.6	15.7	0.1	7.3							
29	晴	13.5	15.9	0.0	7.3							
30	晴	11.9	15.8	0.0	7.4							
平均		14.9	16.2	0.0	7.3	52.5	51.5	124	5.0	<0.03	<0.02	
最高		18.9	16.6	0.2	7.5	52.7	52.5	129	5.0	<0.03	<0.02	
最低		9.2	15.7	0.0	7.3	52.3	50.4	119	4.9	<0.03	<0.02	