

令和7年 2月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	曇	6.6	15.5	0.1	7.3							
2	雨	8.4	15.6	0.0	7.3							
3	曇	9.6	15.7	0.1	7.3							
4	晴	8.0	15.6	0.1	7.3	51.7	52.1	122	5.0	<0.03	<0.02	
5	晴	7.9	15.6	0.1	7.4							
6	晴	7.3	15.4	0.1	7.3							
7	晴	7.5	15.6	0.0	7.4							
8	晴	7.9	15.5	0.1	7.3							
9	晴	8.0	15.4	0.0	7.3							
10	晴	4.0	15.5	0.0	7.3							
11	晴	2.6	15.6	0.0	7.4							
12	曇	4.7	15.8	0.0	7.3							
13	晴	13.3	15.8	0.0	7.4							
14	曇	6.9	15.9	0.0	7.3							
15	晴	5.3	15.7	0.0	7.3							
16	曇	10.9	15.9	0.0	7.2							
17	晴	9.7	16.1	0.1	7.3							
18	曇	5.0	16.1	0.0	7.3	50.5	51.2	115	5.0	<0.03	<0.02	
19	晴	3.5	15.8	0.0	7.3							
20	晴	1.7	15.6	0.0	7.3							
21	晴	1.2	15.6	0.0	7.3							
22	晴	2.3	15.4	0.0	7.2							
23	晴	0.6	15.4	0.0	7.3							
24	晴	2.9	15.7	0.0	7.3							
25	晴	1.5	15.7	0.1	7.3							
26	晴	10.4	15.6	0.0	7.3							
27	晴	5.2	15.7	0.1	7.2							
28	曇	6.3	15.7	0.1	7.3							
平均		6.0	15.7	0.0	7.3	51.1	51.7	119	5.0	<0.03	<0.02	
最高		13.3	16.1	0.1	7.4	51.7	52.1	122	5.0	<0.03	<0.02	
最低		0.6	15.4	0.0	7.2	50.5	51.2	115	5.0	<0.03	<0.02	