

令和7年 3月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	9.5	15.7	0.0	7.3							
2	曇	11.4	15.7	0.0	7.3							
3	雨	10.4	15.6	1.1	7.3							
4	曇	4.5	15.6	0.1	7.3	51.1	50.6	127	5.1	<0.03	<0.02	
5	雨	9.1	15.7	0.1	7.2							
6	曇	11.1	15.9	0.1	7.2							
7	晴	6.5	15.8	0.1	7.3							
8	曇	5.2	15.7	0.0	7.3							
9	曇	6.9	15.6	0.0	7.3							
10	晴	10.6	16.1	0.0	7.4							
11	曇	9.0	16.0	0.1	7.3							
12	曇	12.6	16.3	0.1	7.4							
13	曇	14.0	16.1	0.1	7.3							
14	晴	13.1	16.1	0.0	7.4							
15	曇	9.8	15.8	0.0	7.3							
16	雨	7.1	15.6	0.0	7.3							
17	晴	11.2	15.7	0.1	7.3							
18	晴	8.2	15.8	0.1	7.3	50.4	51.2	120	5.2	<0.03	<0.02	
19	曇	7.4	15.7	0.0	7.3							
20	晴	7.4	15.5	0.1	7.4							
21	晴	6.8	15.8	0.0	7.3							
22	晴	14.9	15.9	0.0	7.4							
23	晴	16.5	16.3	0.0	7.3							
24	曇	15.5	16.0	0.1	7.4							
25	晴	15.1	16.2	0.0	7.3							
26	晴	14.1	16.2	0.1	7.2							
27	晴	19.2	16.2	0.1	7.3							
28	雨	19.5	16.4	0.1	7.2							
29	雨	12.2	15.9	0.1	7.3							
30	晴	10.1	15.9	0.0	7.3							
31	曇	7.7	15.7	0.1	7.4							
平均		10.9	15.9	0.1	7.3	50.8	50.9	124	5.2	<0.03	<0.02	
最高		19.5	16.4	1.1	7.4	51.1	51.2	127	5.2	<0.03	<0.02	
最低		4.5	15.5	0.0	7.2	50.4	50.6	120	5.1	<0.03	<0.02	