

令和7年 4月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(着水井(原水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	雨	9.0	15.7	0.1	7.4							
2	晴	13.9	16.3	0.0	7.4							
3	雨	10.6	16.0	0.1	7.4							
4	晴	12.2	16.3	0.1	7.4							
5	晴	10.3	15.8	0.1	7.4							
6	雨	12.5	15.9	0.0	7.4							
7	晴	11.2	16.1	0.1	7.4	50.5	52.5	126	4.9	<0.03	<0.02	
8	晴	12.8	16.0	0.1	7.4							
9	晴	16.4	16.2	0.1	7.4							
10	晴	16.9	16.3	0.0	7.5							
11	曇	15.8	16.1	0.2	7.4							
12	晴	16.5	16.0	0.0	7.4							
13	雨	13.9	16.2	0.0	7.4							
14	晴	18.1	16.2	0.1	7.4							
15	晴	16.4	16.1	0.1	7.3							
16	晴	13.6	15.9	0.1	7.3							
17	晴	16.6	16.1	0.1	7.3							
18	曇	18.2	16.1	0.1	7.3							
19	晴	21.5	16.3	0.1	7.4							
20	曇	20.8	16.1	0.0	7.3							
21	晴	21.9	16.2	0.0	7.3	50.7	50.8	126	5.0	<0.03	<0.02	
22	曇	19.8	16.4	0.1	7.3							
23	雨	17.9	16.3	0.1	7.3							
24	曇	20.2	16.1	0.1	7.3							
25	曇	18.8	16.2	0.1	7.3							
26	晴	17.7	16.5	0.0	7.3							
27	晴	16.9	15.9	0.1	7.3							
28	曇	16.8	16.1	0.1	7.3							
29	晴	16.4	16.0	0.1	7.2							
30	晴	16.9	16.1	0.1	7.3							
平 均		16.0	16.1	0.1	7.4	50.6	51.7	126	5.0	<0.03	<0.02	
最 高		21.9	16.5	0.2	7.5	50.7	52.5	126	5.0	<0.03	<0.02	
最 低		9.0	15.7	0.0	7.2	50.5	50.8	126	4.9	<0.03	<0.02	