

令和7年11月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイクロストレーナ室(配水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	18.1	15.4	0.0	7.2							
2	曇	13.1	15.4	0.0	7.3							
3	晴	18.0	15.3	0.0	7.3							
4	晴	12.4	15.3	0.1	7.3	49.6	51.6	125	5.6	<0.03	<0.02	
5	曇	12.4	15.4	0.0	7.3							
6	晴	17.0	15.6	0.0	7.5							
7	晴	13.4	15.4	0.1	7.3							
8	晴	17.0										断水作業
9	曇	13.0	15.3	0.0	7.3							
10	晴	18.1	15.4	0.0	7.3							
11	晴	13.1	15.3	0.0	7.3							
12	晴	10.8	15.3	0.0	7.2							
13	曇	11.3	15.3	0.0	7.1							
14	晴	12.0	15.3	0.0	7.2							
15	晴	13.1	15.7	0.0	7.2							
16	晴	13.2	15.3	0.0	7.3							
17	晴	11.9	15.5	0.0	7.2	49.0	52.4	125	5.5	<0.03	<0.02	
18	晴	14.1	15.4	0.0	7.3							
19	晴	8.7	15.4	0.0	7.3							
20	晴	9.2	15.4	0.0	7.3							
21	晴	6.9	15.4	0.0	7.3							
22	晴	9.1	15.2	0.0	7.3							
23	晴	12.7	15.3	0.0	7.3							
24	晴	10.4	15.3	0.0	7.3							
25	曇	12.0	15.4	0.0	7.3							
26	晴	7.9	15.4	0.0	7.3							
27	曇	9.5	15.3	0.0	7.3							
28	晴	15.7	15.3	0.0	7.2							
29	晴	9.2	15.6	0.0	7.3							
30	晴	8.0	15.2	0.0	7.3							
平均		12.4	15.4	0.0	7.3	49.3	52.0	125	5.6	<0.03	<0.02	
最高		18.1	15.7	0.1	7.5	49.6	52.4	125	5.6	<0.03	<0.02	
最低		6.9	15.2	0.0	7.1	49.0	51.6	125	5.5	<0.03	<0.02	