

令和8年 1月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイクロストレーナ室(配水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	3.3	15.1	0.1	7.2							
2	晴	4.7	15.0	0.0	7.2							
3	晴	0.2	15.0	0.0	7.2							
4	晴	0.1	15.0	0.0	7.2							
5	晴	3.4	15.1	0.1	7.2	48.6	51.9	120	5.4	<0.03	<0.02	
6	晴	7.2	15.2	0.0	7.2							
7	曇	5.1	15.2	0.0	7.2							
8	晴	4.2	15.3	0.0	7.2							
9	晴	1.0	15.3	0.0	7.3							
10	晴	2.2	15.2	0.0	7.2							
11	晴	12.2	15.1	0.0	7.3							
12	晴	3.3	15.0	0.0	7.3							
13	晴	6.8	15.1	0.0	7.2							
14	晴	8.4	15.1	0.0	7.2							
15	晴	1.4	15.0	0.0	7.2							
16	晴	13.6	15.5	0.0	7.1							
17	晴	3.9	15.0	0.0	7.1							
18	晴	5.2	15.0	0.0	7.2							
19	晴	8.4	15.2	0.1	7.2	49.0	53.2	124	5.5	<0.03	<0.02	
20	晴	13.1	15.0	0.1	7.2							
21	曇	3.5	14.9	0.0	7.2							
22	晴	2.0	15.0	0.0	7.3							
23	晴	0.2	15.2	0.0	7.2							
24	晴	3.8	15.0	0.0	7.2							
25	晴	1.4	15.0	0.0	7.2							
26	晴	-0.5	15.1	0.0	7.2							
27	晴	3.9	15.0	0.0	7.2							
28	曇	1.8	15.2	0.0	7.2							
29	晴	1.4	15.2	0.0	7.1							
30	晴	0.7	15.1	0.0	7.2							
31	晴	3.3	15.3	0.0	7.1							
平均		4.2	15.1	0.0	7.2	48.8	52.6	122	5.5	<0.03	<0.02	
最高		13.6	15.5	0.1	7.3	49.0	53.2	124	5.5	<0.03	<0.02	
最低		-0.5	14.9	0.0	7.1	48.6	51.9	120	5.4	<0.03	<0.02	