

令和8年 8月分

柿田川工業用水道水質試験結果報告書(1)

採水時間 10:00

日	水質試験結果(マイクロストレーナ室(配水))											備考
	天候	気温 ℃	水温 ℃	濁度 度	pH	アルカリ 度 mg/L	硬度 mg/L	蒸発残 留物 mg/L	塩化物イ オン mg/L	鉄 mg/L	マンガン mg/L	
1	晴	31.6	16.5	0.0	7.3							
2	晴	34.2	15.8	0.1	7.3							
3	曇	27.8	16.0	0.1	7.4	46.7	52.7	134	5.8	<0.03	<0.02	
4	晴	28.5	15.9	0.1	7.1							
5	晴	30.4	15.6	0.1	7.2							
6	晴	31.9	16.0	0.1	7.1							
7	晴	31.3	15.7	0.1	7.2							
8	晴	31.3	16.4	0.0	7.1							
9	晴	30.2	15.6	0.0	7.1							
10	晴	29.4	15.8	0.0	7.3							
11	晴	27.5	16.2	0.0	7.4							
12	雨	23.2	15.7	0.1	7.4							
13	晴	28.8	15.8	0.1	7.3							
14	曇	26.8	16.0	0.1	7.3							
15	晴	27.8	15.5	0.0	7.4							
16	晴	28.6	15.9	0.0	7.4							
17	曇	28.5	15.7	0.2	7.4	46.8	54.0	130	5.9	<0.03	<0.02	
18	晴	29.4	15.6	0.2	7.2							
19	晴	28.5	15.8	0.2	7.2							
20	晴	29.6	15.6	0.1	7.3							
21	晴	28.5	15.6	0.1	7.4							
22	曇	27.1	15.6	0.2	7.4							
23	曇	26.9	15.7	0.0	7.4							
24	晴	28.1	16.0	0.2	7.4							
25	曇	28.5	16.0	0.4	7.4							
26	晴	30.2	16.0	0.1	7.4							
27	晴	30.4	16.0	0.2	7.5							
28	曇	27.3	15.5	0.2	7.4							
29	雨	25.2	15.6	0.1	7.4							
30	雨	22.1	15.3	0.1	7.4							
31	晴	26.4	15.9	0.1	7.4							
平 均		28.6	15.8	0.1	7.3	46.8	53.4	132	5.9	<0.03	<0.02	
最 高		34.2	16.5	0.4	7.5	46.8	54.0	134	5.9	<0.03	<0.02	
最 低		22.1	15.3	0.0	7.1	46.7	52.7	130	5.8	<0.03	<0.02	