

令和3年2月分

東駿河湾工業用水道 岳南水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (厚原浄水場 着水井(原水))									
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	全硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	備考 (日最大 濁度)
1	曇	6.9	7.4	16.8	7.72							24
2	曇	11.0	9.2	7.5	7.72							36
3	晴	5.4	9.1	85.1	7.61	50.0	68.0	183	9.6	22.00	0.06	125
4	晴	7.0	8.5	13.3	7.76							34
5	晴	6.1	8.0	13.8	7.73							40
6	晴	7.0	8.3	9.9	7.61							38
7	晴	9.5	9.0	9.8	7.66							21
8	晴	9.0	9.5	8.9	7.78							16
9	晴	6.0	9.4	5.9	7.70							36
10	晴	4.0	8.0	7.1	7.76							33
11	晴	8.0	8.3	8.3	7.65							26
12	曇	7.1	7.8	6.9	7.78							23
13	晴	12.0	9.1	6.3	7.65							27
14	晴	12.0	9.3	7.6	7.75							44
15	雨	11.8	10.4	15.1	7.77							25
16	晴	12.9	10.0	69.0	7.67							157
17	晴	10.0	9.2	31.1	7.75							48
18	晴	3.2	8.0	14.4	7.72	53.0	69.0	155	10.1	0.84	<0.02	27
19	晴	4.0	8.1	9.8	7.71							27
20	晴	6.0	8.2	6.9	7.70							30
21	晴	12.5	9.5	10.6	7.66							24
22	晴	14.3	11.0	7.6	7.71							18
23	晴	18.0	12.1	5.8	7.76							17
24	曇	8.2	11.0	5.9	7.77							32
25	晴	5.0	9.3	8.7	7.69							25
26	曇	9.0	9.3	6.8	7.71							32
27	晴	8.0	9.5	9.3	7.72							17
28	晴	6.0	8.5	6.9	7.73							26
平均		8.6	9.1	14.8	7.71	51.5	68.5	169	9.9	11.42	0.03	
最高		18.0	12.1	85.1	7.78	53.0	69.0	183	10.1	22.00	0.06	
最低		3.2	7.4	5.8	7.61	50.0	68.0	155	9.6	0.84	<0.02	

令和3年2月分

東駿河湾工業用水道 水質試験結果報告書 (厚原浄水場)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (厚原浄水場 配水池 (配水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	全硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	6.9	7.1	1.7	7.40							
2	曇	11.0	8.2	2.5	7.52							
3	晴	5.4	8.9	2.5	7.30	45.0	69.0	138	9.2	0.06	<0.02	
4	晴	7.0	8.4	3.2	7.54							
5	晴	6.1	7.1	2.2	7.42							
6	晴	7.0	7.7	3.0	7.26							
7	晴	9.5	8.6	2.7	7.66							
8	晴	9.0	9.0	2.9	7.67							
9	晴	6.0	8.4	2.6	7.49							
10	晴	4.0	8.0	2.1	7.47							
11	晴	8.0	8.1	1.6	7.40							
12	曇	7.1	8.4	2.4	7.42							
13	晴	12.0	9.2	1.7	7.40							
14	晴	12.0	9.4	1.9	7.54							
15	雨	11.8	10.7	2.7	7.48							
16	晴	12.9	11.4	2.4	7.50							
17	晴	10.0	9.7	2.5	7.40							
18	晴	3.2	8.8	2.2	7.41	46.0	69.0	131	8.9	0.07	<0.02	
19	晴	4.0	7.7	2.2	7.39							
20	晴	6.0	7.8	2.5	7.38							
21	晴	12.5	8.7	2.4	7.37							
22	晴	14.3	10.0	3.0	7.39							
23	晴	18.0	11.1	2.6	7.59							
24	曇	8.2	11.0	3.0	7.52							
25	晴	5.0	10.2	2.9	7.37							
26	曇	9.0	10.0	2.9	7.48							
27	晴	8.0	9.8	2.3	7.41							
28	晴	6.0	9.0	2.7	7.50							
平均		8.6	9.0	2.5	7.45	45.5	69.0	135	9.1	0.07	<0.02	
最高		18.0	11.4	3.2	7.67	46.0	69.0	138	9.2	0.07	<0.02	
最低		3.2	7.1	1.6	7.26	45.0	69.0	131	8.9	0.06	<0.02	