

令和3年11月分

東駿河湾工業用水道 岳南水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井 (原水))									備考 (日最大濁度)
			水温 °C	濁度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガ ン mg/l	
1	晴	17.0	14.6	4.9	7.92							7
2	曇	18.0	15.6	3.9	7.86	54.2	71.8	140	7.4	0.14	0.03	14
3	晴	17.5	16.0	5.0	7.88							29
4	晴	16.1	16.2	7.4	7.92							25
5	晴	15.2	15.5	9.7	7.88							28
6	晴	15.5	15.4	5.4	7.82							19
7	曇	14.0	14.8	5.3	7.86							20
8	晴	20.6	15.3	5.8	7.93							15
9	雨	15.3	15.2	3.2	7.89							12
10	晴	17.2	14.6	98.7	7.84							116
11	晴	14.8	14.7	17.0	7.87							22
12	晴	15.8	14.0	9.7	7.89							26
13	晴	12.0	13.6	5.1	7.87							21
14	晴	13.0	13.0	4.9	7.81							14
15	晴	14.5	13.2	4.5	7.84							9
16	晴	14.0	13.3	3.9	7.83							22
17	晴	14.0	13.8	6.9	7.82							26
18	晴	14.6	14.3	6.0	7.82							26
19	晴	11.9	13.8	6.1	7.90							28
20	晴	14.0	13.6	12.4	7.83							23
21	曇	13.0	12.8	8.0	7.83							11
22	晴	11.5	13.3	5.1	7.88							8
23	晴	15.0	14.1	9.0	7.80							26
24	晴	14.0	13.3	12.4	7.89	49.9	67.3	127	6.6	0.44	<0.02	38
25	晴	7.5	11.1	7.1	7.88							10
26	晴	12.2	11.4	3.7	7.85							16
27	晴	12.0	11.6	4.8	7.87							13
28	晴	9.0	10.7	4.7	7.88							16
29	曇	7.0	9.2	4.6	7.89							9
30	晴	10.0	10.5	3.1	7.90							18
31												12
平均		13.9	13.6	9.6	7.87	52.1	69.6	134	7.0	0.29	<0.02	
最高		20.6	16.2	98.7	7.93	54.2	71.8	140	7.4	0.44	0.03	
最低		7.0	9.2	3.1	7.80	49.9	67.3	127	6.6	0.14	<0.02	

令和3年11月分

東駿河湾工業用水道 水質試験結果報告書 (厚原浄水場)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	17.0	15.5	1.8	7.68							
2	曇	18.0	15.0	2.2	7.71	50.2	70.0	135	7.6	0.08	<0.02	
3	晴	17.5	15.5	2.1	7.59							
4	晴	16.1	16.5	1.1	7.57							
5	晴	15.2	15.7	2.3	7.53							
6	晴	15.5	15.3	2.6	7.58							
7	曇	14.0	14.8	1.9	7.61							
8	晴	20.6	15.8	2.1	7.58							
9	雨	15.3	15.0	2.2	7.68							
10	晴	17.2	15.3	2.7	7.58							
11	晴	14.8	14.7	2.6	7.42							
12	晴	15.8	14.0	2.5	7.56							
13	晴	12.0	13.8	2.2	7.51							
14	晴	13.0	13.2	2.3	7.60							
15	晴	14.5	13.0	2.0	7.53							
16	晴	14.0	12.9	1.7	7.61							
17	晴	14.0	12.9	2.5	7.46							
18	晴	14.6	13.8	2.0	7.49							
19	晴	11.9	13.9	1.5	7.50							
20	晴	14.0	13.4	1.7	7.51							
21	曇	13.0	13.0	1.7	7.53							
22	晴	11.5	13.3	1.8	7.56							
23	晴	15.0	14.0	1.4	7.65							
24	晴	14.0	13.8	1.7	7.51	39.9	64.9	111	6.5	0.06	<0.02	
25	晴	7.5	11.2	2.3	7.51							
26	晴	12.2	11.5	2.0	7.57							
27	晴	12.0	11.7	2.6	7.60							
28	晴	9.0	11.6	2.6	7.63							
29	曇	7.0	10.4	2.4	7.60							
30	晴	10.0	10.0	2.4	7.80							
31												
平均		13.9	13.7	2.1	7.58	45.1	67.5	123	7.1	0.07	<0.02	
最高		20.6	16.5	2.7	7.80	50.2	70.0	135	7.6	0.08	<0.02	
最低		7.0	10.0	1.1	7.42	39.9	64.9	111	6.5	0.06	<0.02	