

令和3年12月分

東駿河湾工業用水道 岳南水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井(原水))									備考 (日最大濁度)
			水温 °C	濁度	pH	アルカリ度 mg/l	硬度 mg/l	蒸発残留物 mg/l	塩化物イオン mg/l	鉄 mg/l	マンガ ン mg/l	
1	晴	17.8	12.0	4.3	7.86							101
2	晴	10.0	11.0	71.5	7.70							192
3	晴	8.8	10.0	13.3	7.81							36
4	晴	9.0	10.9	7.9	7.76							21
5	晴	7.5	10.0	4.8	7.70							24
6	曇	10.0	9.6	7.0	7.78	54.2	74.7	131	7.9	0.32	<0.02	16
7	曇	12.2	10.0	4.1	7.81							17
8	雨	11.0	10.6	5.9	7.85							19
9	晴	11.0	11.1	11.4	7.75							22
10	曇	9.4	10.8	6.8	7.83							39
11	晴	9.2	10.2	5.8	7.88							21
12	晴	10.0	9.9	5.6	7.87							21
13	晴	11.5	10.1	5.4	7.82							13
14	曇	6.6	10.0	3.9	7.90							20
15	晴	6.2	8.7	4.7	7.73							19
16	晴	10.0	9.8	8.0	7.62							14
17	雨	8.8	9.7	9.2	7.74							25
18	晴	3.0	9.8	14.8	7.78							42
19	晴	3.0	8.7	7.4	7.72							48
20	晴	5.5	7.0	5.4	7.78							18
21	晴	5.8	7.8	3.9	7.76	54.7	69.2	139	8.8	0.72	0.02	18
22	晴	8.0	8.3	4.9	7.68							25
23	晴	7.3	9.0	5.2	7.79							20
24	晴	6.9	8.2	5.7	7.73							18
25	曇	8.8	8.7	4.1	7.78							17
26	晴	4.1	9.0	4.9	7.90							14
27	晴	-0.5	7.0	4.8	7.77							12
28	晴	3.0	6.2	2.5	7.78							13
29	晴	4.0	6.2	5.0	7.79							16
30	晴	7.1	6.7	8.9	7.82							12
31	晴	6.0	7.3	8.5	7.68							10
平均		7.8	9.2	8.6	7.78	54.5	72.0	135	8.4	0.52	0.02	
最高		17.8	12.0	71.5	7.90	54.7	74.7	139	8.8	0.72	0.02	
最低		-0.5	6.2	2.5	7.62	54.2	69.2	131	7.9	0.32	<0.02	

令和3年12月分

東駿河湾工業用水道 水質試験結果報告書 (厚原浄水場)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	17.8	11.0	2.8	7.57							
2	晴	10.0	11.4	1.8	7.57							
3	晴	8.8	10.4	1.6	7.57							
4	晴	9.0	9.8	2.5	7.66							
5	晴	7.5	10.0	2.3	7.63							
6	曇	10.0	9.6	2.2	7.55	49.2	75.3	145	7.7	0.05	<0.02	
7	曇	12.2	10.1	2.1	7.57							
8	雨	11.0	10.6	2.5	7.56							
9	晴	11.0	11.1	2.2	7.45							
10	曇	9.4	10.9	2.3	7.49							
11	晴	9.2	10.8	2.3	7.53							
12	晴	10.0	10.7	2.5	7.53							
13	晴	11.5	10.7	2.0	7.55							
14	曇	6.6	10.2	1.7	7.62							
15	晴	6.2	8.9	2.6	7.34							
16	晴	10.0	9.0	2.7	7.35							
17	雨	8.8	9.3	2.3	7.44							
18	晴	3.0	9.9	2.0	7.46							
19	晴	3.0	9.6	2.0	7.41							
20	晴	5.5	8.0	1.8	7.45							
21	晴	5.8	7.3	1.6	7.52	51.4	75.9	139	8.9	0.06	<0.02	
22	晴	8.0	7.8	2.4	7.40							
23	晴	7.3	8.4	2.0	7.40							
24	晴	6.9	8.0	2.3	7.44							
25	曇	8.8	8.1	2.2	7.50							
26	晴	4.1	9.1	2.1	7.60							
27	晴	-0.5	8.8	1.7	7.43							
28	晴	3.0	7.5	1.3	7.54							
29	晴	4.0	7.3	1.9	7.58							
30	晴	7.1	7.5	1.0	7.60							
31	晴	6.0	7.7	1.4	7.51							
平均		7.8	9.3	2.1	7.51	50.3	75.6	142	8.3	0.06	<0.02	
最高		17.8	11.4	2.8	7.66	51.4	75.9	145	8.9	0.06	<0.02	
最低		-0.5	7.3	1.0	7.34	49.2	75.3	139	7.7	0.05	<0.02	