

令和4年12月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	14.2	14.2	46.7	7.76							
2	晴	12.0	12.4	23.9	7.78							
3	曇	9.0	11.8	6.9	7.75							
4	晴	9.0	11.3	5.5	7.77							
5	曇	12.4	11.6	4.4	7.84							
6	曇	11.0	12.2	4.2	7.80							
7	晴	8.5	11.6	3.2	7.78	55.0	67.7	136	7.8	0.16	<0.02	
8	晴	7.6	10.8	4.3	7.81							
9	曇	8.2	10.3	3.6	7.81							
10	晴	9.5	9.9	5.5	7.84							
11	晴	10.0										断水
12	晴	9.4	11.0	13.1	7.83							
13	雨	7.8	10.1	4.5	7.81							
14	晴	13.0	10.6	5.5	7.87							
15	晴	4.8	9.8	3.9	7.87							
16	晴	6.4	9.2	3.4	7.84							
17	曇	7.0	8.6	3.4	7.80							
18	晴	8.1	8.9	3.1	7.90							
19	晴	2.5	8.6	3.5	7.90							
20	晴	2.9	7.7	5.9	7.87	55.3	69.4	148	8.7	0.33	<0.02	
21	曇	5.0	7.6	3.3	7.88							
22	雨	6.8	7.8	5.8	7.80							
23	晴	5.8	8.0	24.4	7.74							
24	晴	3.5	7.0	9.5	7.72							
25	晴	5.0	6.3	7.7	7.73							
26	晴	3.0	6.6	4.6	7.81							
27	晴	6.0	7.1	3.7	7.82							
28	晴	5.0	7.0	3.7	7.89							
29	晴	12.5	8.0	1.5	7.73							
30	晴	4.8	7.2	14.2	7.71							
31	曇	6.0	7.4	2.8	7.72							
平均		7.6	9.4	7.9	7.81	55.2	68.6	142	8.3	0.25	<0.02	
最高		14.2	14.2	46.7	7.90	55.3	69.4	148	8.7	0.33	<0.02	
最低		2.5	6.3	1.5	7.71	55.0	67.7	136	7.8	0.16	<0.02	

令和4年12月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	14.2	14.6	1.7	7.30							
2	晴	12.0	13.5	1.5	7.34							
3	曇	9.0	12.5	1.8	7.46							
4	晴	9.0	11.7	2.2	7.48							
5	曇	12.4	11.7	1.1	7.52							
6	曇	11.0	12.2	1.7	7.66							
7	晴	8.5	12.0	1.9	7.65	52.5	71.2	130	6.8	0.08	<0.02	
8	晴	7.6	11.6	1.9	7.64							
9	曇	8.2	10.7	2.2	7.61							
10	晴	9.5	10.7	1.7	7.68							
11	晴	10.0										断水
12	晴	9.4	10.9	1.1	7.72							
13	雨	7.8	10.4	2.9	7.64							
14	晴	13.0	10.3	1.6	7.61							
15	晴	4.8	10.1	2.1	7.65							
16	晴	6.4	9.5	1.8	7.56							
17	曇	7.0	8.9	1.9	7.57							
18	晴	8.1	9.1	1.8	7.58							
19	晴	2.5	9.0	1.6	7.64							
20	晴	2.9	8.0	1.0	7.69	53.3	68.0	144	8.3	分析装置故障のため鉄・マンガンデータなし		
21	曇	5.0	7.4	1.5	7.61							
22	雨	6.8	7.7	2.1	7.61							
23	晴	5.8	7.8	1.9	7.52							
24	晴	3.5	7.4	2.3	7.65							
25	晴	5.0	6.9	1.5	7.47							
26	晴	3.0	6.9	1.2	7.50							
27	晴	6.0	6.9	1.2	7.61							
28	晴	5.0	7.8	2.1	7.58							
29	晴	12.5	8.2	1.0	7.68							
30	晴	4.8	7.7	1.2	7.68							
31	曇	6.0	7.8	1.5	7.60							
平均		7.6	9.7	1.7	7.58	52.9	69.6	137	7.6	0.08	<0.02	
最高		14.2	14.6	2.9	7.72	53.3	71.2	144	8.3	0.08	<0.02	
最低		2.5	6.9	1.0	7.30	52.5	68.0	130	6.8	0.08	<0.02	