

令和6年12月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	9.0	11.1	4.8	7.76							
2	晴	8.3	11.2	3.7	7.72	53.6	69.5	152	6.8	0.15	0.02	
3	晴	9.0	11.4	6.8	7.78							
4	晴	11.4	11.7	7.2	7.73							
5	曇	11.0	11.8	8.0	7.79							
6	晴	7.7	11.3	10.7	7.73							
7	晴	9.8	10.7	10.0	7.85							
8	晴	8.0										計画断水
9	晴	7.0	10.2	10.6	7.79							
10	晴	6.6	9.1	3.8	7.76							
11	晴	8.8	9.5	3.8	7.80							
12	晴	7.0	9.5	2.4	7.83							
13	曇	4.5	8.8	3.1	7.81							
14	晴	10.5	8.9	4.7	7.78							
15	晴	4.0	8.7	3.8	7.84							
16	晴	5.2	8.5	1.8	7.81	56.7	70.2	142	8.0	0.08	<0.02	
17	晴	6.2	8.9	2.4	7.84							
18	晴	6.4	8.3	6.1	7.83							
19	曇	7.0	9.2	14.5	7.80							
20	晴	5.6	8.8	2.7	7.81							
21	晴	5.8	8.3	2.4	7.80							
22	晴	9.5	8.1	6.8	7.80							
23	晴	4.5	8.6	2.2	7.82							
24	晴	4.6	7.7	10.5	7.44							
25	晴	3.1	7.7	3.5	7.70							
26	晴	7.7	8.3	2.8	7.46							
27	晴	7.2	8.7	3.9	7.81							
28	晴	4.0	7.9	5.1	7.76							
29	晴	3.0	7.5	6.3	7.75							
30	曇	4.5	7.6	8.1	7.72							
31	晴	4.5	7.5	6.2	7.65							
平均		6.8	9.2	5.6	7.76	55.2	69.9	147	7.4	0.12	<0.02	
最高		11.4	11.8	14.5	7.85	56.7	70.2	152	8.0	0.15	0.02	
最低		3.0	7.5	1.8	7.44	53.6	69.5	142	6.8	0.08	<0.02	

令和6年12月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	9.0	11.0	1.6	7.63							
2	晴	8.3	11.0	1.5	7.51	50.3	72.7	131	7.0	0.04	<0.02	
3	晴	9.0	11.6	1.2	7.52							
4	晴	11.4	12.0	1.9	7.53							
5	曇	11.0	12.0	1.7	7.49							
6	晴	7.7	11.8	1.9	7.49							
7	晴	9.8	11.5	2.3	7.51							
8	晴	8.0										計画断水
9	晴	7.0	11.2	1.3	7.55							
10	晴	6.6	10.1	2.1	7.56							
11	晴	8.8	9.6	1.8	7.52							
12	晴	7.0	9.6	1.7	7.53							
13	曇	4.5	9.3	1.6	7.47							
14	晴	10.5	8.7	1.8	7.55							
15	晴	4.0	8.7	1.8	7.67							
16	晴	5.2	8.8	1.4	7.54	51.5	69.4	140	8.3	0.04	<0.02	
17	晴	6.2	8.6	1.7	7.65							
18	晴	6.4	9.0	1.7	7.58							
19	曇	7.0	9.0	2.2	7.45							
20	晴	5.6	8.9	1.7	7.51							
21	晴	5.8	8.7	2.2	7.54							
22	晴	9.5	8.6	2.3	7.55							
23	晴	4.5	8.5	1.6	7.33							
24	晴	4.6	8.2	2.6	7.17							
25	晴	3.1	7.8	2.0	7.23							
26	晴	7.7	8.4	2.1	7.22							
27	晴	7.2	8.3	1.9	7.33							
28	晴	4.0	8.9	2.1	7.35							
29	晴	3.0	8.6	1.7	7.38							
30	曇	4.5	8.6	1.3	7.53							
31	晴	4.5	8.5	0.9	7.37							
平均		6.8	9.5	1.8	7.48	50.9	71.1	136	7.7	0.04	<0.02	
最高		11.4	12.0	2.6	7.67	51.5	72.7	140	8.3	0.04	<0.02	
最低		3.0	7.8	0.9	7.17	50.3	69.4	131	7.0	0.04	<0.02	