

令和7年1月分

ふじさん工業用水道(東駿河湾) 水質試験結果報告書(岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井(原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	6.0	8.0	4.1	7.50							
2	晴	5.0	9.5	3.0	7.77							
3	晴	6.0	8.2	4.0	7.59							
4	晴	3.0	9.5	3.0	7.75							
5	晴	4.0	8.8	3.0	7.71							
6	雨	5.2	7.3	2.0	7.61	57.5	73.0	140	8.3	0.10	0.04	
7	曇	6.2	7.2	2.5	7.81							
8	晴	5.3	8.1	8.5	7.60							
9	晴	3.5	7.4	3.4	7.79							
10	晴	0.7	7.3	4.2	7.81							
11	晴	3.5	7.1	2.8	7.74							
12	曇	3.8	7.9	4.0	7.85							
13	晴	5.5	7.5	3.5	7.82							
14	晴	6.5	8.1	2.7	7.90							
15	晴	10.0	8.1	3.2	7.88							
16	晴	4.0	7.5	7.7	7.79							
17	晴	4.0	7.0	4.0	7.76							
18	曇	5.0	7.9	3.8	7.75							
19	晴	5.8	7.7	4.6	7.90							
20	晴	8.4	8.4	3.3	7.91	57.6	75.7	150	10.8	0.13	0.04	
21	晴	8.0	10.1	3.6	7.94							
22	晴	8.0	10.0	4.5	7.73							
23	晴	6.0	10.4	6.0	7.85							
24	晴	6.5	9.4	6.3	7.86							
25	晴	7.8	9.5	4.8	7.89							
26	晴	8.1	8.9	5.8	7.87							
27	曇	2.5	7.7	3.9	7.74							
28	晴	7.1	8.0	3.4	7.85							
29	晴	7.1	9.5	4.3	7.78							
30	晴	5.0	8.2	3.8	7.79							
31	晴	4.2	8.2	4.3	7.79							
平均		5.5	8.3	4.1	7.78	57.6	74.4	145	9.6	0.12	0.04	
最高		10.0	10.4	8.5	7.94	57.6	75.7	150	10.8	0.13	0.04	
最低		0.7	7.0	2.0	7.50	57.5	73.0	140	8.3	0.10	0.04	

令和7年1月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	6.0	8.5	1.5	7.18							
2	晴	5.0	8.4	1.1	7.35							
3	晴	6.0	8.7	1.3	7.36							
4	晴	3.0	8.4	1.4	7.53							
5	晴	4.0	8.4	1.3	7.50							
6	雨	5.2	8.6	1.1	7.32	53.0	72.7	139	8.0	0.05	<0.02	
7	曇	6.2	8.0	1.4	7.64							
8	晴	5.3	8.3	2.2	7.28							
9	晴	3.5	7.8	2.1	7.38							
10	晴	0.7	7.5	2.2	7.47							
11	晴	3.5	7.3	2.2	7.51							
12	曇	3.8	7.1	1.7	7.51							
13	晴	5.5	7.4	1.4	7.48							
14	晴	6.5	8.0	1.0	7.55							
15	晴	10.0	8.3	1.9	7.62							
16	晴	4.0	8.0	2.0	7.57							
17	晴	4.0	7.8	1.9	7.54							
18	曇	5.0	7.7	2.3	7.50							
19	晴	5.8	7.8	2.3	7.53							
20	晴	8.4	8.1	2.1	7.46	53.4	75.5	145	11.3	0.05	<0.02	
21	晴	8.0	9.4	1.4	7.55							
22	晴	8.0	10.0	2.0	7.53							
23	晴	6.0	9.4	2.1	7.46							
24	晴	6.5	9.4	2.1	7.48							
25	晴	7.8	9.6	2.4	7.46							
26	晴	8.1	9.8	2.2	7.56							
27	曇	2.5	9.0	2.8	7.55							
28	晴	7.1	8.7	1.9	7.65							
29	晴	7.1	8.7	2.1	7.57							
30	晴	5.0	8.2	2.2	7.48							
31	晴	4.2	8.5	2.2	7.51							
平均		5.5	8.4	1.9	7.49	53.2	74.1	142	9.7	0.05	<0.02	
最高		10.0	10.0	2.8	7.65	53.4	75.5	145	11.3	0.05	<0.02	
最低		0.7	7.1	1.0	7.18	53.0	72.7	139	8.0	0.05	<0.02	