

令和7年2月分

ふじさん工業用水道(東駿河湾) 水質試験結果報告書(岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 着水井(原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	5.5	8.0	4.5	7.69							
2	雨	5.8	7.7	4.1	7.81							
3	曇	6.8	8.7	4.6	7.70	56.9	72.6	140	11.2	0.10	<0.02	
4	晴	6.0	9.3	11.6	7.63							
5	晴	4.2	9.0	6.5	7.73							
6	晴	1.8	7.4	3.6	7.77							
7	晴	3.7	7.4	4.0	7.75							
8	晴	4.0	7.3	4.8	7.66							
9	晴	5.0	7.2	7.4	7.68							
10	晴	4.2	7.4	4.1	7.70							
11	晴	6.0	8.2	6.9	7.67							
12	曇	4.2	8.1	5.8	7.64							
13	晴	14.8	9.0	4.0	7.71							
14	曇	6.9	9.8	7.4	7.61							
15	晴	7.5	9.2	4.6	7.66							
16	晴	8.0	9.2	5.0	7.62							
17	曇	8.4	9.8	10.9	7.62	57.3	70.8	168	11.2	0.12	<0.02	
18	曇	4.3	10.1	4.0	7.69							
19	晴	5.3	8.5	4.6	7.66							
20	晴	5.0	8.0	5.2	7.56							
21	晴	4.8	8.2	3.5	7.67							
22	晴	4.9	7.8	5.2	7.72							
23	晴	4.2	7.7	6.2	7.62							
24	晴	5.5	7.9	4.3	7.57							
25	晴	4.0	7.6	3.1	7.62							
26	晴	6.9	8.9	5.2	7.67							
27	晴	9.0	9.5	4.7	7.65							
28	晴	10.0	10.0	5.1	7.65							
29												
30												
31												
平均		6.0	8.5	5.4	7.67	57.1	71.7	154	11.2	0.11	<0.02	
最高		14.8	10.1	11.6	7.81	57.3	72.6	168	11.2	0.12	<0.02	
最低		1.8	7.2	3.1	7.56	56.9	70.8	140	11.2	0.10	<0.02	

令和7年2月分

ふじさん工業用水道(東駿河湾) 水質試験結果報告書(岳南)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (厚原浄水場 配水池(浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	5.5	7.9	1.6	7.32							
2	雨	5.8	8.2	1.8	7.49							
3	曇	6.8	8.9	2.0	7.24	53.2	71.5	133	11.0	0.05	<0.02	
4	晴	6.0	9.6	1.9	7.38							
5	晴	4.2	9.0	1.6	7.50							
6	晴	1.8	8.0	1.3	7.51							
7	晴	3.7	7.4	2.1	7.42							
8	晴	4.0	7.2	2.3	7.41							
9	晴	5.0	7.3	2.2	7.42							
10	晴	4.2	7.4	2.2	7.46							
11	晴	6.0	7.5	1.8	7.54							
12	曇	4.2	7.6	2.4	7.42							
13	晴	14.8	8.0	1.5	7.46							
14	曇	6.9	9.5	2.3	7.44							
15	晴	7.5	8.8	2.4	7.46							
16	晴	8.0	9.3	2.2	7.44							
17	曇	8.4	10.0	2.4	7.46	53.5	71.1	149	11.9	0.11	<0.02	
18	曇	4.3	10.2	2.2	7.49							
19	晴	5.3	9.3	2.0	7.50							
20	晴	5.0	8.3	2.4	7.44							
21	晴	4.8	7.8	1.8	7.47							
22	晴	4.9	8.4	2.0	7.51							
23	晴	4.2	8.3	2.3	7.40							
24	晴	5.5	8.1	1.7	7.40							
25	晴	4.0	8.2	1.3	7.47							
26	晴	6.9	8.0	2.0	7.49							
27	晴	9.0	9.0	2.5	7.42							
28	晴	10.0	9.5	2.4	7.45							
29												
30												
31												
平均		6.0	8.5	2.0	7.44	53.4	71.3	141	11.5	0.08	<0.02	
最高		14.8	10.2	2.5	7.54	53.5	71.5	149	11.9	0.11	<0.02	
最低		1.8	7.2	1.3	7.24	53.2	71.1	133	11.0	0.05	<0.02	