

令和8年2月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (岳南)

採水時間 9:00

| 日 | 天候 | 気温 °C | 水質試験結果 (厚原浄水場 着水井 (原水)) | | | | | | | | 備考 | |
|----|----|----------|-------------------------|---------|------|-------------------|------------|-------------------|--------------------|-----------|-------|------------------|
| | | | 水温 °C | 濁度 度 | pH | アルカリ 度 mg/l | 硬度 mg/l | 蒸発 残留物 mg/l | 塩化物 イオン mg/l | 鉄 mg/l | | マン ガン mg/l |
| 1 | 晴 | 1.0 | 6.4 | 4.5 | 7.65 | | | | | | | |
| 2 | 晴 | 3.7 | 7.3 | 4.1 | 7.65 | 60.4 | 78.6 | 167 | 12.7 | 0.16 | <0.02 | |
| 3 | 晴 | 6.0 | 8.0 | 3.5 | 7.65 | | | | | | | |
| 4 | 晴 | 5.0 | 8.2 | 3.9 | 7.58 | | | | | | | |
| 5 | 晴 | 5.0 | 8.0 | 4.5 | 7.66 | | | | | | | |
| 6 | 晴 | 7.2 | 8.5 | 3.9 | 7.68 | | | | | | | |
| 7 | 雨 | 6.0 | 8.2 | 3.4 | 7.60 | | | | | | | |
| 8 | 晴 | 5.0 | 8.1 | 6.2 | 7.58 | | | | | | | |
| 9 | 晴 | 0.0 | 6.9 | 2.7 | 7.60 | | | | | | | |
| 10 | 晴 | 3.0 | 6.0 | 2.2 | 7.55 | | | | | | | |
| 11 | 雨 | 6.0 | 6.8 | 2.2 | 7.58 | | | | | | | |
| 12 | 雨 | 4.7 | 7.1 | 7.9 | 7.63 | | | | | | | |
| 13 | 曇 | 5.0 | 8.0 | 5.6 | 7.62 | | | | | | | |
| 14 | 晴 | 8.5 | 8.9 | 7.2 | 7.65 | | | | | | | |
| 15 | 晴 | 9.5 | 8.9 | 6.9 | 7.62 | | | | | | | |
| 16 | 晴 | 11.0 | 10.6 | 6.4 | 7.65 | 59.4 | 78.5 | 168 | 13.1 | 0.14 | <0.02 | |
| 17 | 雨 | 4.1 | 9.4 | 3.5 | 7.60 | | | | | | | |
| 18 | 晴 | 6.0 | 9.0 | 4.2 | 7.62 | | | | | | | |
| 19 | 晴 | 6.7 | 9.1 | 3.8 | 7.53 | | | | | | | |
| 20 | 曇 | 5.5 | 9.5 | 3.7 | 7.49 | | | | | | | |
| 21 | 晴 | 6.0 | 9.5 | 4.4 | 7.50 | | | | | | | |
| 22 | 晴 | 9.0 | 10.0 | 4.5 | 7.54 | | | | | | | |
| 23 | 曇 | 15.5 | 11.6 | 4.3 | 7.67 | | | | | | | |
| 24 | 晴 | 12.5 | 12.5 | 3.6 | 7.56 | | | | | | | |
| 25 | 雨 | 15.0 | 12.1 | 15.0 | 7.60 | | | | | | | |
| 26 | 晴 | 13.0 | 12.6 | 12.5 | 7.61 | | | | | | | |
| 27 | 晴 | 13.0 | 13.0 | 5.6 | 7.62 | | | | | | | |
| 28 | 晴 | 13.0 | 13.6 | 11.8 | 7.62 | | | | | | | |
| 平均 | | 7.4 | 9.2 | 5.4 | 7.60 | 59.9 | 78.5 | 168 | 12.9 | 0.15 | <0.02 | |
| 最高 | | 15.5 | 13.6 | 15.0 | 7.68 | 60.4 | 78.6 | 168 | 13.1 | 0.16 | <0.02 | |
| 最低 | | 0.0 | 6.0 | 2.2 | 7.49 | 59.4 | 78.5 | 167 | 12.7 | 0.14 | <0.02 | |

令和8年2月分

ふじさん工業用水道 (東駿河湾) 水質試験結果報告書 (岳南)

採水時間 9:00

| 日 | 天候 | 気温 °C | 水質試験結果 (厚原浄水場 配水池 (浄水)) | | | | | | | | | 備考 |
|----|----|----------|--------------------------|---------|------|-------------------|------------|-------------------|--------------------|-----------|------------------|----|
| | | | 水温 °C | 濁度 度 | pH | アルカリ 度 mg/l | 硬度 mg/l | 蒸発 残留物 mg/l | 塩化物 イオン mg/l | 鉄 mg/l | マン ガン mg/l | |
| 1 | 晴 | 1.0 | 7.2 | 1.1 | 7.28 | | | | | | | |
| 2 | 晴 | 3.7 | 7.2 | 1.6 | 7.36 | 53.7 | 79.8 | 155 | 12.9 | 0.04 | <0.02 | |
| 3 | 晴 | 6.0 | 7.5 | 1.0 | 7.39 | | | | | | | |
| 4 | 晴 | 5.0 | 8.0 | 1.1 | 7.37 | | | | | | | |
| 5 | 晴 | 5.0 | 8.0 | 1.4 | 7.43 | | | | | | | |
| 6 | 晴 | 7.2 | 8.4 | 0.9 | 7.40 | | | | | | | |
| 7 | 雨 | 6.0 | 8.5 | 1.0 | 7.38 | | | | | | | |
| 8 | 晴 | 5.0 | 8.7 | 1.2 | 7.40 | | | | | | | |
| 9 | 晴 | 0.0 | 7.8 | 1.2 | 7.42 | | | | | | | |
| 10 | 晴 | 3.0 | 6.5 | 1.5 | 7.39 | | | | | | | |
| 11 | 雨 | 6.0 | 6.6 | 1.4 | 7.55 | | | | | | | |
| 12 | 雨 | 4.7 | 7.6 | 0.9 | 7.38 | | | | | | | |
| 13 | 曇 | 5.0 | 8.0 | 1.1 | 7.32 | | | | | | | |
| 14 | 晴 | 8.5 | 8.4 | 1.6 | 7.35 | | | | | | | |
| 15 | 晴 | 9.5 | 8.9 | 1.3 | 7.30 | | | | | | | |
| 16 | 晴 | 11.0 | 9.8 | 1.2 | 7.41 | 53.2 | 78.7 | 162 | 13.2 | 0.04 | <0.02 | |
| 17 | 雨 | 4.1 | 10.1 | 1.2 | 7.37 | | | | | | | |
| 18 | 晴 | 6.0 | 10.0 | 1.5 | 7.30 | | | | | | | |
| 19 | 晴 | 6.7 | 9.1 | 1.2 | 7.30 | | | | | | | |
| 20 | 曇 | 5.5 | 9.3 | 1.5 | 7.31 | | | | | | | |
| 21 | 晴 | 6.0 | 9.1 | 0.8 | 7.30 | | | | | | | |
| 22 | 晴 | 9.0 | 9.8 | 1.4 | 7.35 | | | | | | | |
| 23 | 曇 | 15.5 | 11.0 | 1.4 | 7.40 | | | | | | | |
| 24 | 晴 | 12.5 | 11.5 | 2.2 | 7.46 | | | | | | | |
| 25 | 雨 | 15.0 | 12.3 | 2.0 | 7.38 | | | | | | | |
| 26 | 晴 | 13.0 | 12.0 | 1.4 | 7.42 | | | | | | | |
| 27 | 晴 | 13.0 | 11.8 | 2.2 | 7.47 | | | | | | | |
| 28 | 晴 | 13.0 | 13.0 | 1.4 | 7.37 | | | | | | | |
| 平均 | | 7.4 | 9.1 | 1.3 | 7.38 | 53.4 | 79.3 | 159 | 13.1 | 0.04 | <0.02 | |
| 最高 | | 15.5 | 13.0 | 2.2 | 7.55 | 53.7 | 79.8 | 162 | 13.2 | 0.04 | <0.02 | |
| 最低 | | 0.0 | 6.5 | 0.8 | 7.28 | 53.2 | 78.7 | 155 | 12.9 | 0.04 | <0.02 | |