

令和2年 5月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	15.0	15.4	22.1	7.79							
2	晴	16.0	16.2	20.6	7.83							
3	曇	18.0	17.3	17.4	7.84							
4	雨	16.0	16.0	12.3	7.84							
5	晴	18.5	16.0	13.7	7.97							
6	晴	17.5	17.1	26.6	7.88							
7	晴	15.0	16.4	22.7	7.81							
8	晴	16.0	15.8	30.3	7.81							
9	曇	14.0	15.1	29.0	7.81							
10	雨	18.0	14.6	22.3	7.82							
11	曇	19.0	15.6	515	7.83							
12	晴	18.0	17.6	321	7.86							
13	晴	18.0	17.2	95.5	7.81	44.0	61.0	226	4.3	4.31	0.08	
14	晴	18.5	17.0	73.0	7.88							
15	晴	17.0	16.6	37.6	7.82							
16	雨	17.0	16.8	20.5	7.83							
17	晴	18.0	15.5	70.2	7.87							
18	晴	20.0	18.5	86.7	7.82							
19	雨	17.0	17.3	58.4	7.81							
20	曇	17.0	17.4	235	7.73	39.0	56.0	358	2.7	10.41	0.23	
21	曇	14.0	16.7	148	7.87							
22	晴	15.0	14.5	105	7.80							
23	晴	17.0	17.0	55.3	7.80							
24	曇	19.0	18.0	32.8	7.78							
25	曇	14.0	18.3	25.4	7.86							
26	曇	19.5	18.5	37.0	7.82							
27	晴	21.0	17.7	18.2	7.91							
28	曇	20.5	19.3	29.7	7.80							
29	晴	20.0	18.1	40.0	7.82							
30	晴	23.0	17.8	29.5	7.86							
31	曇	19.0	18.1	24.9	7.92							
平均		17.6	16.9	73.4	7.84	41.5	58.5	292	3.5	7.36	0.16	
最高		23.0	19.3	515	7.97	44.0	61.0	358	4.3	10.41	0.23	
最低		14.0	14.5	12.3	7.73	39.0	56.0	226	2.7	4.31	0.08	

令和2年 5月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	15.0	14.8	0.6	7.48							
2	晴	16.0	15.4	0.6	7.47							
3	曇	18.0	16.3	0.6	7.46							
4	雨	16.0	16.6	0.4	7.51							
5	晴	18.5	16.4	1.3	7.60							
6	晴	17.5	17.2	0.9	7.62							
7	晴	15.0	16.7	0.8	7.56							
8	晴	16.0	15.8	1.0	7.34							
9	曇	14.0	15.2	0.7	7.39							
10	雨	18.0	15.1	0.9	7.52							
11	曇	19.0	16.0	0.8	7.54							
12	晴	18.0	16.5	0.4	7.34							
13	晴	18.0	16.9	0.6	7.42	36.0	59.0	103	8.2	0.03	<0.02	
14	晴	18.5	17.3	0.6	7.44							
15	晴	17.0	16.5	0.8	7.40							
16	雨	17.0	16.7	0.6	7.39							
17	晴	18.0	16.2	0.4	7.50							
18	晴	20.0	17.1	0.5	7.44							
19	雨	17.0	17.8	0.8	7.35							
20	曇	17.0	17.3	0.6	7.35	34.0	54.0	98	6.9	0.03	<0.02	
21	曇	14.0	17.0	0.6	7.47							
22	晴	15.0	15.7	1.0	7.46							
23	晴	17.0	16.3	0.7	7.41							
24	曇	19.0	17.5	0.5	7.48							
25	曇	14.0	18.3	0.5	7.55							
26	曇	19.5	18.8	0.5	7.49							
27	晴	21.0	18.4	0.6	7.49							
28	曇	20.5	18.9	0.6	7.42							
29	晴	20.0	19.3	0.4	7.47							
30	晴	23.0	18.7	0.5	7.49							
31	曇	19.0	18.4	0.5	7.46							
平均		17.6	16.9	0.6	7.46	35.0	56.5	101	7.5	0.03	<0.02	
最高		23.0	19.3	1.3	7.62	36.0	59.0	103	8.2	0.03	<0.02	
最低		14.0	14.8	0.4	7.34	34.0	54.0	98	6.9	0.03	<0.02	