

令和 2年 8月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	24.0	20.4	125	7.80							
2	晴	24.0	20.3	94.1	7.80							
3	晴	23.5	20.4	74.6	7.81							
4	晴	26.0	21.5	199	7.77							
5	晴	26.5	22.0	68.9	7.77	44.0	55.0	174	2.6	2.68	0.07	
6	曇	25.0	22.5	67.0	7.81							
7	晴	23.5	22.0	60.8	7.85							
8	曇	27.5	22.0	48.5	7.81							
9	曇	26.0	22.6	36.5	7.81							
10	晴	26.0	22.8	30.9	7.82							
11	晴	26.0	23.1	25.0	7.83							
12	晴	28.0	23.8	23.5	7.89							
13	晴	28.5	24.0	31.2	7.82							
14	晴	27.0	23.5	14.1	7.87							
15	晴	28.5	24.4	15.1	7.86							
16	晴	29.5	24.9	11.3	7.82							
17	曇	29.5	25.3	9.3	7.89							
18	晴	27.0	24.8	22.0	7.95							
19	晴	28.0	24.9	24.8	7.85	53.0	67.0	150	4.5	0.89	0.03	
20	晴	27.5	24.3	21.3	7.95							
21	曇	27.5	25.1	16.1	7.88							
22	晴	28.0	25.4	15.9	7.81							
23	曇	23.0	23.3	235	7.75							
24	晴	23.0	23.8	20.6	7.77							
25	曇	26.0	23.8	24.9	7.75							
26	晴	23.5	24.4	15.2	7.80							
27	晴	26.5	24.6	23.3	7.87							
28	曇	25.5	24.6	32.5	7.77							
29	晴	25.5	23.7	30.4	7.80							
30	晴	27.5	25.3	18.2	7.93							
31	曇	26.0	25.3	10.7	7.81							
平均		26.2	23.5	46.6	7.83	48.5	61.0	162	3.6	1.79	0.05	
最高		29.5	25.4	235	7.95	53.0	67.0	174	4.5	2.68	0.07	
最低		23.0	20.3	9.3	7.75	44.0	55.0	150	2.6	0.89	0.03	

令和 2年 8月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	24.0	20.6	0.8	7.30							
2	晴	24.0	21.2	0.5	7.48							
3	晴	23.5	21.2	0.7	7.43							
4	晴	26.0	21.9	0.8	7.27							
5	晴	26.5	22.4	0.5	7.42	37.0	52.0	105	5.3	0.03	<0.02	
6	曇	25.0	23.0	0.8	7.35							
7	晴	23.5	22.7	1.0	7.32							
8	曇	27.5	23.2	0.8	7.33							
9	曇	26.0	23.4	0.9	7.40							
10	晴	26.0	24.0	0.9	7.32							
11	晴	26.0	23.4	1.2	7.49							
12	晴	28.0	24.3	1.0	7.54							
13	晴	28.5	24.8	0.7	7.49							
14	晴	27.0	24.4	0.9	7.52							
15	晴	28.5	24.5	0.8	7.59							
16	晴	29.5	25.1	0.7	7.52							
17	曇	29.5	25.9	0.8	7.67							
18	晴	27.0	25.4	1.1	7.67							
19	晴	28.0	25.3	0.9	7.56	48.0	68.0	128	4.0	0.06	<0.02	
20	晴	27.5	25.3	0.9	7.70							
21	曇	27.5	25.6	0.8	7.62							
22	晴	28.0	26.0	1.0	7.60							
23	曇	23.0	25.1	1.0	7.61							
24	晴	23.0	23.8	1.1	7.39							
25	曇	26.0	24.8	0.6	7.45							
26	晴	23.5	24.8	0.7	7.50							
27	晴	26.5	25.3	0.7	7.58							
28	曇	25.5	25.2	0.8	7.45							
29	晴	25.5	24.1	1.0	7.50							
30	晴	27.5	25.2	0.5	7.62							
31	曇	26.0	26.1	0.5	7.57							
平均		26.2	24.1	0.8	7.45	42.5	60.0	117	4.7	0.05	<0.02	
最高		29.5	26.1	1.2	7.70	48.0	68.0	128	5.3	0.06	<0.02	
最低		23.0	20.6	0.5	7.27	37.0	52.0	105	4.0	0.03	<0.02	