

令和 2年11月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	10.0	18.2	24.2	7.95							
2	曇	12.0	13.5	13.6	7.87							
3	曇	15.0	14.2	27.1	7.90							
4	晴	10.5	14.8	29.1	7.93							
5	晴	11.5	13.1	39.8	7.88							
6	晴	10.0	12.9	16.6	7.91							
7	曇	13.0	13.3	23.2	7.83							
8	曇	15.0	13.2	34.1	7.88							
9	晴	13.5	14.0	33.6	7.92							
10	晴	8.0	13.1	37.1	7.83							
11	晴	11.5	12.2	38.5	7.84	52.0	67.0	159	6.5	1.37	0.04	
12	晴	6.5	11.8	34.9	7.88							
13	晴	10.0	12.2	15.5	7.84							
14	晴	13.5	13.0	20.9	7.84							
15	晴	7.0	12.4	19.3	7.84							
16	晴	11.5	12.4	7.8	7.82							
17	晴	13.0	13.2	23.7	7.85							
18	曇	13.0	13.0	27.6	7.89							
19	晴	15.0	14.3	26.1	7.86	54.0	64.0	153	7.8	1.24	0.02	
20	曇	18.0	15.3	23.6	7.84							
21	晴	14.5	15.4	36.9	7.80							
22	晴	8.5	13.5	27.0	7.86							
23	晴	13.0	13.2	5.9	7.84							
24	晴	12.0	13.8	12.7	7.84							
25	晴	12.5	13.0	21.6	7.85							
26	晴	8.0	13.3	28.1	7.86							
27	晴	11.5	13.2	23.3	7.86							
28	晴	15.0	12.5	20.0	7.84							
29	晴	8.0	11.8	20.6	7.89							
30	晴	7.5	11.2	6.0	7.84							
31												
平均		11.6	13.4	23.9	7.86	53.0	65.5	156	7.2	1.31	0.03	
最高		18.0	18.2	39.8	7.95	54.0	67.0	159	7.8	1.37	0.04	
最低		6.5	11.2	5.9	7.80	52.0	64.0	153	6.5	1.24	0.02	

令和 2年11月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	10.0	13.6	0.8	7.54							
2	曇	12.0	13.4	1.2	7.59							
3	曇	15.0	14.0	0.7	7.52							
4	晴	10.5	14.8	1.0	7.48							
5	晴	11.5	14.0	2.0	7.53							
6	晴	10.0	13.1	0.5	7.55							
7	曇	13.0	13.4	0.9	7.56							
8	曇	15.0	14.1	0.9	7.58							
9	晴	13.5	14.4	0.9	7.40							
10	晴	8.0	13.8	1.2	7.48							
11	晴	11.5	12.7	1.1	7.46	45.0	64.0	125	6.1	0.04	<0.02	
12	晴	6.5	12.4	1.0	7.49							
13	晴	10.0	12.3	0.6	7.54							
14	晴	13.5	12.9	0.9	7.56							
15	晴	7.0	12.8	0.8	7.62							
16	晴	11.5	12.5	0.9	7.59							
17	晴	13.0	13.2	0.8	7.64							
18	曇	13.0	13.4	0.7	7.63							
19	晴	15.0	14.2	0.9	7.57	50.0	62.0	129	7.6	0.04	<0.02	
20	曇	18.0	15.3	1.6	7.55							
21	晴	14.5	15.4	1.4	7.57							
22	晴	8.5	14.9	1.4	7.53							
23	晴	13.0	13.3	1.0	7.62							
24	晴	12.0	14.0	1.2	7.62							
25	晴	12.5	13.6	1.1	7.62							
26	晴	8.0	13.4	1.2	7.49							
27	晴	11.5	13.5	1.3	7.61							
28	晴	15.0	13.4	1.2	7.65							
29	晴	8.0	12.8	0.9	7.66							
30	晴	7.5	11.6	1.0	7.67							
31												
平均		11.6	13.5	1.0	7.56	47.5	63.0	127	6.9	0.04	<0.02	
最高		18.0	15.4	2.0	7.67	50.0	64.0	129	7.6	0.04	<0.02	
最低		6.5	11.6	0.5	7.40	45.0	62.0	125	6.1	0.04	<0.02	