

令和 3年 2月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.0	7.9	4.5	7.83							
2	雨	12.5	9.2	7.9	7.65							
3	晴	0.0	8.9	54.8	7.73	52.0	70.0	190	9.5	2.25	0.06	
4	晴	0.0	8.0	20.0	7.73							
5	晴	0.0	7.1	14.4	7.75							
6	晴	3.0	7.9	9.6	7.74							
7	晴	3.0	9.1	9.8	7.75							
8	晴	7.5	9.1	6.1	7.73							
9	晴	2.5	8.3	5.7	7.76							
10	晴	-1.0	7.5	5.9	7.70							
11	晴	2.0	7.8	6.2	7.82							
12	曇	4.5	9.0	5.6	7.84							
13	晴	7.5	9.0	7.3	7.72							
14	曇	10.5	10.2	7.1	7.74							
15	雨	11.0	12.4	10.9	7.77							
16	晴	9.0	9.5	172	7.61							
17	晴	7.0	9.0	25.6	7.74							
18	晴	-2.0	7.4	11.0	7.71	54.0	70.0	147	10.4	0.94	0.02	
19	晴	2.0	7.7	17.7	7.76							
20	晴	0.0	8.2	5.9	7.75							
21	晴	5.0	9.2	9.3	7.77							
22	晴	5.5	10.7	6.4	7.79							
23	晴	16.0	11.9	5.5	7.72							
24	曇	6.5	11.2	5.3	7.78							
25	晴	4.0	10.0	6.4	7.70							
26	曇	6.0	9.7	6.3	7.74							
27	曇	3.0	9.2	5.6	7.74							
28	曇	0.0	9.0	9.7	7.76							
平均		4.5	9.1	16.5	7.74	53.0	70.0	169	10.0	1.60	0.04	
最高		16.0	12.4	172	7.84	54.0	70.0	190	10.4	2.25	0.06	
最低		-2.0	7.1	4.5	7.61	52.0	70.0	147	9.5	0.94	0.02	

令和 3年 2月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	2.0	7.2	1.1	7.54							
2	雨	12.5	8.8	1.4	7.47							
3	晴	0.0	9.1	1.0	7.46	46.0	72.0	130	12.4	0.04	<0.02	
4	晴	0.0	8.1	0.9	7.38							
5	晴	0.0	7.7	1.1	7.38							
6	晴	3.0	7.4	0.9	7.40							
7	晴	3.0	8.2	1.4	7.39							
8	晴	7.5	8.7	0.6	7.46							
9	晴	2.5	8.1	0.6	7.60							
10	晴	-1.0	7.5	0.8	7.50							
11	晴	2.0	7.4	1.4	7.54							
12	曇	4.5	8.3	1.4	7.47							
13	晴	7.5	8.8	1.2	7.50							
14	曇	10.5	8.9	1.3	7.48							
15	雨	11.0	11.7	1.3	7.48							
16	晴	9.0	10.7	2.4	7.38							
17	晴	7.0	9.3	1.1	7.39							
18	晴	-2.0	8.1	1.0	7.50	48.0	69.0	133	9.9	0.06	<0.02	
19	晴	2.0	7.6	1.2	7.53							
20	晴	0.0	7.4	1.1	7.54							
21	晴	5.0	8.0	0.7	7.54							
22	晴	5.5	9.6	0.8	7.51							
23	晴	16.0	11.7	0.7	7.56							
24	曇	6.5	10.8	0.6	7.56							
25	晴	4.0	9.9	1.0	7.53							
26	曇	6.0	9.5	1.1	7.54							
27	曇	3.0	9.2	0.9	7.52							
28	曇	0.0	8.6	1.2	7.57							
平均		4.5	8.8	1.1	7.49	47.0	70.5	132	11.2	0.05	<0.02	
最高		16.0	11.7	2.4	7.60	48.0	72.0	133	12.4	0.06	<0.02	
最低		-2.0	7.2	0.6	7.38	46.0	69.0	130	9.9	0.04	<0.02	