

令和 3年 3月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 ℃	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 ℃	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	8.0	9.7	5.6	7.77							
2	雨	12.0	11.3	4.3	7.68							
3	晴	5.5	10.4	28.6	7.75							
4	曇	4.5	9.5	11.1	7.74							
5	曇	9.5	11.1	6.5	7.77							
6	曇	9.5	11.0	6.1	7.79							
7	曇	9.5	13.2	7.6	7.79							
8	雨	7.5	9.7	8.2	7.77							
9	晴	7.0	10.6	18.9	7.71							
10	晴	8.0	11.4	9.7	7.75	57.0	76.0	154	11.3	0.62	0.02	
11	晴	6.0	12.6	19.2	7.82							
12	曇	10.0	12.4	8.6	7.80							
13	雨	7.5	10.5	9.2	7.77							
14	晴	8.5	9.4	52.9	7.63							
15	晴	11.0	11.6	21.1	7.77							
16	晴	5.5	12.0	18.7	7.75							
17	晴	10.0	12.9	8.2	7.76	56.0	75.0	146	9.3	0.83	0.02	
18	晴	8.0	12.6	12.1	7.75							
19	晴	9.5	12.9	19.8	7.77							
20	晴	11.0	13.2	39.9	7.78							
21	雨	13.5	13.6	27.2	7.79							
22	晴	11.0	11.5	1,224	7.94							
23	晴	5.0	9.3	159	7.63							
24	晴	4.5	10.2	61.3	7.74							
25	晴	9.0	11.6	48.3	7.78							
26	晴	8.0	11.4	24.5	7.80							
27	晴	9.5	11.9	50.5	7.81							
28	曇	13.0	12.9	12.0	7.86							
29	晴	13.0	12.6	21.3	7.75							
30	晴	12.5	13.1	93.6	7.73							
31	晴	13.0	14.2	13.3	7.72							
平均		9.0	11.6	66.2	7.76	56.5	75.5	150	10.3	0.73	0.02	
最高		13.5	14.2	1,224	7.94	57.0	76.0	154	11.3	0.83	0.02	
最低		4.5	9.3	4.3	7.63	56.0	75.0	146	9.3	0.62	0.02	

令和 3年 3月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	8.0	9.1	1.1	7.56							
2	雨	12.0	10.6	0.7	7.49							
3	晴	5.5	10.4	1.5	7.56							
4	曇	4.5	9.8	1.2	7.45							
5	曇	9.5	10.5	1.0	7.47							
6	曇	9.5	10.7	1.3	7.54							
7	曇	9.5	11.6	1.0	7.56							
8	雨	7.5	11.2	1.7	7.59							
9	晴	7.0	10.3	0.9	7.46							
10	晴	8.0	11.1	0.8	7.56	52.0	75.0	134	10.0	0.05	<0.02	
11	晴	6.0	11.8	1.0	7.55							
12	曇	10.0	12.0	1.0	7.48							
13	雨	7.5	10.5	0.9	7.54							
14	晴	8.5	10.7	1.9	7.46							
15	晴	11.0	10.7	1.0	7.44							
16	晴	5.5	11.2	0.7	7.48							
17	晴	10.0	12.1	1.0	7.49	51.0	74.0	131	8.8	0.04	<0.02	
18	晴	8.0	12.2	1.0	7.48							
19	晴	9.5	12.4	0.9	7.48							
20	晴	11.0	13.2	1.0	7.54							
21	雨	13.5	13.8	1.0	7.56							
22	晴	11.0	13.7	1.1	7.47							
23	晴	5.0	10.7	0.7	7.27							
24	晴	4.5	10.2	1.1	7.32							
25	晴	9.0	11.3	0.7	7.34							
26	晴	8.0	11.6	0.8	7.37							
27	晴	9.5	12.3	0.8	7.46							
28	曇	13.0	12.5	0.9	7.47							
29	晴	13.0	13.0	1.0	7.45							
30	晴	12.5	12.7	0.8	7.33							
31	晴	13.0	13.7	0.8	7.40							
平均		9.0	11.5	1.0	7.47	51.5	74.5	133	9.4	0.05	<0.02	
最高		13.5	13.8	1.9	7.59	52.0	75.0	134	10.0	0.05	<0.02	
最低		4.5	9.1	0.7	7.27	51.0	74.0	131	8.8	0.04	<0.02	