

令和3年7月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	20.0	20.4	21.2	7.79							
2	雨	20.5	18.9	79.1	7.66							
3	雨	23.0	20.1	290.0	7.59							
4	雨	21.0	20.3	339.0	7.59							
5	曇	22.0	18.9	194.0	7.75	42.1	43.7	318	3.0	7.84	0.19	
6	曇	23.5	19.1	219.0	7.76							
7	曇	24.5	18.3	160.0	7.71							
8	曇	24.0	19.7	90.8	7.77							
9	雨	23.5	18.9	85.5	7.65							
10	晴	24.5	19.3	163.0	7.74							
11	晴	25.5	20.6	97.5	7.76							
12	晴	25.5	20.8	65.7	7.72							
13	晴	23.0	20.2	36.2	7.78							
14	曇	24.0	20.5	246.0	7.71	39.5	64.5	608	2.3	23.56	0.70	
15	曇	22.0	20.4	86.6	7.84							
16	晴	26.5	19.9	62.8	7.76							
17	晴	25.0	20.8	39.6	7.77							
18	晴	27.5	21.1	26.0	7.78							
19	晴	26.5	22.3	19.4	7.79							
20	晴	26.0	22.8	19.3	7.80							
21	晴	26.5	22.6	18.1	7.82							
22	晴	24.5	23.0	9.8	7.91							
23	晴	26.5	23.6	11.4	7.83							
24	晴	27.0	23.7	9.4	7.84							
25	晴	24.0	23.0	13.1	7.86							
26	晴	26.5	23.6	10.1	7.89							
27	雨	25.5	23.1	9.4	8.10							
28	曇	24.5	22.0	11.2	8.04							
29	曇	26.5	23.2	9.3	8.15							
30	晴	25.0	23.2	9.5	8.03							
31	曇	25.0	24.2	9.1	7.94							
平均		24.5	21.2	79.4	7.81	40.8	54.1	463	2.6	15.70	0.44	
最高		27.5	24.2	339.0	8.15	42.1	64.5	608	3.0	23.56	0.70	
最低		20.0	18.3	9.1	7.59	39.5	43.7	318	2.3	7.84	0.19	

令和3年7月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	20.0	20.9	0.8	7.49							
2	雨	20.5	19.9	1.0	7.45							
3	雨	23.0	20.2	0.9	7.30							
4	雨	21.0	19.6	0.7	7.22							
5	曇	22.0	19.9	0.6	7.33	34.4	49.9	115	8.3	0.11	<0.02	
6	曇	23.5	20.0	0.9	7.38							
7	曇	24.5	20.4	0.7	7.40							
8	曇	24.0	20.0	0.8	7.43							
9	雨	23.5	20.4	1.2	7.35							
10	晴	24.5	20.3	1.0	7.40							
11	晴	25.5	20.9	0.8	7.43							
12	晴	25.5	21.0	0.7	7.32							
13	晴	23.0	21.1	1.1	7.37							
14	曇	24.0	21.3	0.7	7.42	36.9	54.7	98	3.6	0.04	<0.02	
15	曇	22.0	20.8	0.6	7.40							
16	晴	26.5	20.5	1.0	7.47							
17	晴	25.0	20.9	0.8	7.41							
18	晴	27.5	20.9	1.0	7.42							
19	晴	26.5	22.4	1.2	7.56							
20	晴	26.0	22.7	0.7	7.51							
21	晴	26.5	23.0	0.8	7.58							
22	晴	24.5	23.1	0.7	7.61							
23	晴	26.5	20.8	0.9	7.62							
24	晴	27.0	24.2	1.0	7.62							
25	晴	24.0	23.4	1.0	7.57							
26	晴	26.5	23.9	0.9	7.55							
27	雨	25.5	23.5	0.6	7.59							
28	曇	24.5	23.6	0.9	7.57							
29	曇	26.5	23.5	1.0	7.60							
30	晴	25.0	23.9	1.1	7.62							
31	曇	25.0	24.4	1.3	7.68							
平均		24.5	21.7	0.9	7.47	35.6	52.3	107	5.9	0.07	<0.02	
最高		27.5	24.4	1.3	7.68	36.9	54.7	115	8.3	0.11	<0.02	
最低		20.0	19.6	0.6	7.22	34.4	49.9	98	3.6	0.04	<0.02	