

令和3年11月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	14.5	14.2	3.2	7.84							
2	晴	14.0	15.5	4.0	7.85	53.5	71.6	144	8.2	0.19	<0.02	
3	晴	14.5	16.2	25.1	7.87							
4	晴	14.0	15.7	23.5	7.86							
5	晴	15.0	14.9	37.1	7.86							
6	晴	13.0	15.1	4.3	7.77							
7	曇	12.5	14.8	13.6	7.84							
8	晴	15.5	14.9	4.9	7.86							
9	雨	15.0	15.2	6.4	7.88							
10	晴	10.5	14.1	103.0	7.74							
11	晴	14.0	13.8	21.2	7.82							
12	晴	8.0	13.7	9.4	7.85							
13	晴	7.0	13.0	9.9	7.79							
14	晴	9.0	12.4	12.8	7.82							
15	晴	8.0	12.9	4.4	7.83							
16	晴	10.5	13.0	5.3	7.80							
17	曇	11.0	13.6	9.7	7.81							
18	晴	9.0	13.6	12.0	7.79							
19	晴	10.0	13.5	30.6	7.84							
20	晴	9.5	13.1	7.7	7.81							
21	曇	10.5	13.1	5.7	7.80							
22	曇	11.0	13.7	3.7	7.71							
23	晴	10.5	13.6	19.5	7.73							
24	晴	10.0	11.8	17.3	7.75	54.1	71.1	133	6.8	0.61	0.02	
25	晴	3.5	10.6	12.2	7.78							
26	晴	7.5	10.9	14.1	7.78							
27	晴	8.0	11.4	3.2	7.74							
28	晴	8.0	10.0	11.4	7.81							
29	晴	5.0	9.7	3.1	7.78							
30	晴	7.0	10.5	3.4	7.78							
31												
平均		10.5	13.3	14.7	7.81	53.8	71.4	139	7.5	0.40	<0.02	
最高		15.5	16.2	103.0	7.88	54.1	71.6	144	8.2	0.61	0.02	
最低		3.5	9.7	3.1	7.71	53.5	71.1	133	6.8	0.19	<0.02	

令和3年11月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	14.5	14.5	0.2	7.77							
2	晴	14.0	15.3	0.3	7.76	51.6	72.7	133	9.4	0.04	<0.02	
3	晴	14.5	16.4	0.5	7.76							
4	晴	14.0	16.4	0.6	7.73							
5	晴	15.0	15.5	0.5	7.75							
6	晴	13.0	15.5	0.6	7.74							
7	曇	12.5	15.2	0.5	7.75							
8	晴	15.5	15.1	0.5	7.77							
9	雨	15.0	15.6	0.3	7.80							
10	晴	10.5	15.0	1.2	7.59							
11	晴	14.0	14.8	0.2	7.51							
12	晴	8.0	13.5	0.2	7.52							
13	晴	7.0	13.2	0.0	7.53							
14	晴	9.0	12.6	0.0	7.47							
15	晴	8.0	12.5	0.0	7.49							
16	晴	10.5	13.0	0.0	7.48							
17	曇	11.0	13.4	0.4	7.58							
18	晴	9.0	13.6	0.4	7.66							
19	晴	10.0	13.8	0.4	7.58							
20	晴	9.5	13.1	0.2	7.42							
21	曇	10.5	13.0	0.4	7.29							
22	曇	11.0	13.2	0.2	7.32							
23	晴	10.5	14.1	0.1	7.33							
24	晴	10.0	12.4	0.5	7.08	34.4	63.0	114	6.6	0.01	<0.02	
25	晴	3.5	10.9	0.4	7.30							
26	晴	7.5	11.1	0.5	7.40							
27	晴	8.0	11.0	0.6	7.37							
28	晴	8.0	11.1	0.3	7.42							
29	晴	5.0	9.8	0.3	7.42							
30	晴	7.0	10.0	0.2	7.50							
31												
平均		10.5	13.5	0.3	7.54	43.0	67.8	124	8.0	0.03	<0.02	
最高		15.5	16.4	1.2	7.80	51.6	72.7	133	9.4	0.04	<0.02	
最低		3.5	9.8	0.0	7.08	34.4	63.0	114	6.6	0.01	<0.02	