

令和3年12月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 分水井 (原水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	16.5	11.5	18.2	7.77							
2	晴	3.0	9.8	45.3	7.70							
3	晴	5.0	9.4	10.4	7.71							
4	晴	2.5	9.5	12.2	7.74							
5	晴	6.5	9.8	5.1	7.77							
6	曇	8.5	9.6	5.6	7.70	54.7	74.8	135	8.1	0.33	0.02	
7	曇	12.5	10.1	8.6	7.74							
8	雨	9.0	10.9	6.1	7.73							
9	晴	6.0	10.6	20.6	7.71							
10	晴	6.5	10.8	12.4	7.76							
11	晴	6.0	10.1	25.6	7.80							
12	晴	6.5	10.2	10.0	7.78							
13	晴	7.0	10.3	4.6	7.75							
14	曇	7.0	9.7	7.0	7.77							
15	晴	4.0	8.7	9.2	7.80							
16	晴	4.0	9.4	15.7	7.83							
17	雨	9.5	9.9	15.5	7.82							
18	晴	1.5	9.4	20.6	7.78							
19	晴	-1.0	7.3	7.3	7.77							
20	晴	-0.5	6.7	3.6	7.75							
21	晴	1.0	7.6	6.2	7.75	54.6	70.9	147	9.5	0.49	<0.02	
22	晴	1.5	8.2	14.6	7.75							
23	晴	8.0	9.0	16.2	7.81							
24	晴	5.0	8.4	4.8	7.82							
25	雨	8.5	9.1	10.6	7.80							
26	晴	2.0	9.2	5.6	7.81							
27	晴	-2.0	6.7	3.4	7.81							
28	晴	-1.0	6.3	2.3	7.83							
29	晴	0.0	6.8	4.4	7.77							
30	晴	1.5	7.3	4.3	7.68							
31	晴	4.0	7.1	3.6	7.80							
平均		4.8	9.0	10.9	7.77	54.6	72.9	141	8.8	0.41	<0.02	
最高		16.5	11.5	45.3	7.83	54.7	74.8	147	9.5	0.49	0.02	
最低		-2.0	6.3	2.3	7.68	54.6	70.9	135	8.1	0.33	<0.02	

令和3年12月分

東駿河湾工業用水道 静清庵水質試験結果報告書

採水時間 8:30

日	天候	気温 °C	水質試験結果 (富士川浄水場 浄水池 (浄水))									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	16.5	11.5	0.3	7.43							
2	晴	3.0	10.8	0.8	7.32							
3	晴	5.0	9.8	0.5	7.18							
4	晴	2.5	9.4	0.4	7.26							
5	晴	6.5	9.8	0.4	7.34							
6	曇	8.5	9.5	0.4	7.30	46.2	75.5	134	7.8	0.02	<0.02	
7	曇	12.5	10.3	0.3	7.41							
8	雨	9.0	10.7	0.3	7.34							
9	晴	6.0	11.0	0.3	7.28							
10	晴	6.5	11.0	0.3	7.41							
11	晴	6.0	10.4	0.3	7.39							
12	晴	6.5	10.1	0.4	7.39							
13	晴	7.0	10.5	0.4	7.42							
14	曇	7.0	10.2	0.3	7.48							
15	晴	4.0	8.7	0.7	7.59							
16	晴	4.0	9.3	1.0	7.62							
17	雨	9.5	9.7	1.0	7.61							
18	晴	1.5	9.3	1.1	7.56							
19	晴	-1.0	8.0	1.0	7.51							
20	晴	-0.5	6.7	1.1	7.57							
21	晴	1.0	7.1	1.0	7.59	51.3	71.1	133	8.7	0.05	<0.02	
22	晴	1.5	7.9	1.3	7.63							
23	晴	8.0	8.7	0.9	7.65							
24	晴	5.0	8.2	0.7	7.64							
25	雨	8.5	8.8	1.1	7.54							
26	晴	2.0	9.0	0.9	7.60							
27	晴	-2.0	7.5	1.1	7.64							
28	晴	-1.0	6.1	0.6	7.62							
29	晴	0.0	6.3	0.8	7.57							
30	晴	1.5	7.1	0.9	7.49							
31	晴	4.0	6.8	0.6	7.60							
平均		4.8	9.0	0.7	7.48	48.7	73.3	134	8.3	0.03	<0.02	
最高		16.5	11.5	1.3	7.65	51.3	75.5	134	8.7	0.05	<0.02	
最低		-2.0	6.1	0.3	7.18	46.2	71.1	133	7.8	0.02	<0.02	